




From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 28 June 2021 12:12
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Raymond Cole <Raymond.Cole@arun.gov.uk>
Subject: BE/93/21/DOC

Dear Planning,

Please could the applicant confirm by dwelling type whether or not Table 2.2 of the Parking Standards is complied with? (for ease of reference – 100% of parking spaces with active EV charging points for houses with a driveway or garage, and 30% of all other developments).

Regards

Fiona

Fiona Fitzgerald
Senior Environmental Health Officer
Environmental Health



T: 01903 737674
E: fiona.fitzgerald@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

