

From: Thomas Callaway
Sent: 10 September 2014 16:44
To: Planning.Responses
Subject: RE: Planning Consultation on BE/95/14/DOC

It was originally requested that infiltration was investigated. This would be a suitable method of surface water drainage if it has been confirmed that ground conditions allow for it and that there is no contamination on site. We have no results of any groundwater monitoring or percolation testing, or confirmation that the site is not contaminated.

The highway is to be adopted, West Sussex County Council Highways should be consulted to ensure that drainage is to an adoptable standard.

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: Thomas.Callaway@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit our web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 28 August 2014 10:33
To: Thomas Callaway
Subject: Planning Consultation on BE/95/14/DOC

To: **Engineers (Fluvial Flooding)**

**NOTIFICATION FROM ARUN DISTRICT COUNCIL
TOWN AND COUNTRY PLANNING ACT 1990**

APPLICATION BE/95/14/DOC
NO:

Registered: 14-AUG-14
Site Address: Oldlands Farm Steyning Way Bognor Regis PO22 9NN

Description of Works:

Application for approval of details reserved by conditions 3 (surface water drainage) and 6 (sustainable drainage principles) following a grant of planning permission BE/61/13/.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 11th September 2014.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr N Crowther who can be contacted on telephone number 01903737500 Ex 37839.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
