

From: Thomas Callaway
Sent: 22 September 2014 14:01
To: Peter Cleveland
Subject: RE: BE/95/14/DOC

Peter

The Hydrock report shows that soil infiltration rates will not permit soakage at this location. Therefore the proposed method of surface water drainage can be considered acceptable. We (or West Sussex CC Highways) would now require construction drawings for the headwall showing all levels including the ditch bed. Any silt and vegetation should be removed from the ditches so that the proposed drainage will work as designed.

The condition should be discharged once the EA are happy that pollution concerns have been addressed and West Sussex Highways have accepted the drainage as adoptable.

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: Thomas.Callaway@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit our web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.