

From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 05 July 2021 16:38

To: Simon Davis <Simon.Davis@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Beech Cottage, 99A, North Bersted Street, Bersted, Bognor Regis, West Sussex, PO22 9AF - BE/95/21/DOC

Planning Application Reference: BE/95/21/DOC

Proposal: Approval of details reserved by condition following BE/133/16/PL relating to conditions 9-landscape scheme, 10-dust bin enclosure, 11-placement of 4 nesting opportunities & roosting structure, 12-cycle parking, & 16-lighting details.

Address: Beech Cottage, 99A, North Bersted Street, Bersted, Bognor Regis, West Sussex, PO22 9AF

Dear Simon,

Condition 16 – Lighting details

Further information is required for this condition to be discharged. The condition requires the applicant to submit details of the following.

1. The type of lighting appliance – please supply a data sheet from the manufacturer
2. The height of light fittings
3. Illumination levels – please provide a site plan showing luminance levels of light spill area

The above information remains outstanding. I am therefore unable to recommend discharge of condition 16 – lighting details, at this time.

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltrovers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

