

From: Sue Howell
Sent: 10 August 2017 15:24
To: Planning.Responses
Cc: David Innes
Subject: RE: Planning Consultation on BE/96/17/DOC

Comment from Greenspace

Further to submission of Option 1 Playdale Dwg Scheme no: 29613 rev 4/HAM 30/11/16 containing LEAP detail, we confirm that that the paly equipment proposed is suitable for location, giving a good range of play offer. We would however request that the fencing type is changed to metal bow top at appropriate height, rather than vertical slatted timber fence as shown. We would also require that the gates are connected to pathways for ease of access by users and wheeled users and that any gate bordering a road is inward rather than outward opening.

We would not recommend the discharge of Condition 6 on application BE/96/17/DOC imposed under application BE/122/10 until the fencing detail above is amended and submitted for approval.

Sue Howell | Leisure and Landscape Officer, Greenspace, Engineering and Emergency Planning, Arun District Council | Location: Bognor Regis Town Hall, Clarence Road, Bognor Regis, West Sussex, PO21 1LD
Internal: 37943 | External: +44 (0) 1903 737943 | E-mail: sue.howell@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 07 August 2017 12:33
To: Parks
Subject: Planning Consultation on BE/96/17/DOC

To: Parks and Landscapes

**NOTIFICATION FROM ARUN DISTRICT COUNCIL
TOWN AND COUNTRY PLANNING ACT 1990**

APPLICATION NO: BE/96/17/DOC

Registered: 24-JUL-17
Site Address: Site 6 Chichester Road North Bersted Bersted
PO21 5DR

Description of Application for approval of details reserved by

Works: conditions imposed on planning permission
BE/122/10 relating to conditions 4 (General
arrangement external works) & 6 (LEAP details)

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 21st August 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is David Innes who can be contacted on telephone number 01903 737776.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
