

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>
Sent: 21 February 2020 12:20
To: Finlay Gardner <Finlay.Gardner@arun.gov.uk>
Cc: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: BN/100/19/HH- Orchard End Highground Lane

Hi Finlay,

Yes that's fine. Please ask that the surface water drainage is constructed in accordance with these three documents (PL101C Orchard End, PL102A Orchard End, T-MD-43576_TR_MD1 (4m x 3m x 0.4m)).

Kind Regards

Sarah

From: Finlay Gardner <Finlay.Gardner@arun.gov.uk>
Sent: 19 February 2020 10:52
To: Sarah Burrow <Sarah.Burrow@arun.gov.uk>
Subject: FW: BN/100/19/HH- Orchard End Highground Lane

Hi Sarah,

The agent came back with these, is this enough to not include PCENG2 in the application?

Thanks,

Finlay



Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Nicholas Wood [REDACTED]
Sent: 12 February 2020 21:25
To: Finlay Gardner <Finlay.Gardner@arun.gov.uk>
Subject: Re: BN/100/19/HH- Orchard End Highground Lane

Dear Mr Gardner,

Further to my email this morning, the designers have now re-run the soakaway calculations with the base coefficient set to 0 and this has resulted in a larger soakaway, so please find attached revised drawings and calculations. Please disregard the drawings I sent this morning.

Kind regards,

Nik Wood
Director




On 12 Feb 2020, at 08:08, Nicholas Wood [REDACTED] wrote:

Dear Mr Gardner,

Thank you for your email, I have revised the drawing for points 2 and 3 in accordance with their request, and have asked the soakaway designers to re-run the calculations as requested, which I am still waiting on. I'll forward these on as soon as I receive them.

Kind regards,

Nik Wood
Director



with the registered address 32a Church Road, Chichester, West Sussex. PO19 7HL.
Company registration number : 08644051

<PL101B Orchard End.pdf>

On 31 Jan 2020, at 15:16, Finlay Gardner <Finlay.Gardner@arun.gov.uk> wrote:

Dear Mr Wood,

Following your previous email the drainage team have come back with a further three points:

1. We do not normally approve schemes which account infiltration through the base of a soakaway in their design calculations. This is in accordance with BRE365 and due to the risk of silt reducing the infiltration rate. The applicant has included a silt trap so could make an argument for going through the base, however this will mean delegating the decision to the Principle Drainage Engineer which will cause further delays to the process. Alternatively they can adjust the calculations to show an 'Infiltration Coefficient Base' as zero.
2. Please show an indication of the location of the silt trap on the Proposed Section.
3. Please include a construction detail for the pipe bed and surround (I appreciate they have got a description but point 11 of the guidance notes states that this is required).

If you can provided the needed information I will try and get the application moving forward as swiftly as possible.

Kind regards

Finlay Gardner

[Finlay Gardner](#) | Planning Officer, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37915 | External: +44 (0) 1903 737915 | E-mail: finlay.gardner@arun.gov.uk

<image002.jpg>

Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.


From: Nicholas Wood [REDACTED]
Sent: 24 January 2020 13:18
To: Finlay Gardner <Finlay.Gardner@arun.gov.uk>
Subject: Re: BN/100/19/HH- Orchard End Highground Lane

Dear Mr Gardner,

Apologies for the delay, it's taken a while for the revised drainage calculations to come back to me. Please find attached revised calculations, revised drawing 101, new plan 102, and completed checklist for the proposals.

Kind regards,

Nik Wood
Director




On 13 Jan 2020, at 13:02, Nicholas Wood  wrote:

Dear Mr Gardner,

Thank you for your email last week, sorry for my slow reply I was away. I will forward the required additional information to you this week, and updated calculations to show the 40% allowance rather than 30% which was designed.

Kind regards,

Nik Wood
Director



On 7 Jan 2020, at 09:52, Finlay Gardner
<Finlay.Gardner@arun.gov.uk> wrote:

Dear Mr Wood,

I have received this email from our drainage engineer:

'Apologies for the delay in getting back to you on this. We would require more information to remove the condition. Essentially they need to provide the same level of detail as if they were discharging the applied condition.

As a minimum (and following a brief review) we would require further detail of the groundwater monitoring and infiltration testing. I understand

that this has been completed, however the results have not been supplied.

In addition, the soakaway needs to be designed for up to 1 in 100 year **+40%** and we would expect a silt trap and details of this to be shown. It is strongly advised that the applicant completes and submits a surface water drainage design checklist available at: <https://www.arun.gov.uk/download.cfm?doc=docm93ijm4n14067.pdf&ver=14313>

This should all be fairly straightforward to complete and submit if the testing has been completed in accordance with BRE365.'

If you are able to address the comments that are outlined then I will be able to remove the condition.

I look forward to hearing your response,
Kind regards,

Finlay Gardner

Finlay Gardner | Planning Officer, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37915 | External: +44 (0) 1903 737915 | E-mail: finlay.gardner@arun.gov.uk
Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

<http://www.arun.gov.uk>
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>
Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-

mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused.
Any reference to "e-mail" in this disclaimer includes any attachments.
