

## Environmental Health Consultation Response

<b>To</b>	Kathryn Welch
<b>Date</b>	14-02-2025
<b>Planning Ref</b>	BN/11/25/PIP
<b>Site Description</b>	Land South Of Wandleys Lane Eastergate West Sussex
<b>Date of Application</b>	2025-01-30 00:00:00
<b>Category</b>	Permission In Principle
<b>Recommendation</b>	<del>No Objection</del>  <del>No Objection – with conditions</del>  <del>Objection</del>  <del>Holding Objection</del>

### EH Comments:

**I have considered the above application and while I have no objections in principle if a full application it to be submitted it is likely that we would recommend the following conditions**

### Conditions Recommended:

#### **EHN23 : Building services plant (BS4142:2014+A1:2019)**

No internally or externally located plant, machinery equipment or building services plant including air source heat pumps shall be operated on the site until an assessment of the acoustic impact arising from the operation of all such equipment has been submitted to and approved in writing by the Local Planning Authority. The assessment shall be undertaken in accordance with BS 4142:2014+A1:2019 and shall include a scheme of attenuation measures to mitigate the adverse impacts identified in the acoustic assessment. The scheme shall ensure that the rating level of noise emitted from the proposed building services plant is 5 dB less than the prevailing background sound level (LA90). The scheme as approved by the Local Planning Authority shall be fully installed prior to first operation of the plant and shall be retained as such thereafter. Any agreed attenuation measures shall be permanently maintained in good working condition.

The applicant should review the Planning Noise Advice Document – Sussex, November 2023:

<https://www.arun.gov.uk/download.cfm?doc=docm93jjm4n19846.pdf&ver=24686>.

**Reason:**

To protect the amenity of local residents and avoid background noise creep in accordance with the Arun Local Plan policy QE DM1.

**LIGHT01 : Lighting scheme****combined EH and Ecology**

Prior to the occupation of any part of the development, full details of all new external lighting, including type of light appliance, the height and position of fitting, predicted illumination levels and light spillage, shall be submitted to and approved in writing by the Local Planning Authority. The scheme should seek to conform with the recommendations of the Institute of Lighting Professionals (ILP) 'Guidance Notes for the Reduction of Obtrusive Light' (GN01:2011) and:

a)

identify those areas/features on site that are particularly sensitive for bats and that are likely to cause disturbance in or around their breeding sites and resting places or along important routes used to access key areas of their territory, for example, for foraging

b)

show how and where external lighting will be installed through provision of appropriate lighting contour plans and technical specifications so that it can be clearly demonstrated that areas to be lit will not disturb or prevent the above species using their territory or having access to their breeding sites and resting places.

All external lighting shall be installed in accordance with the specifications and locations set out in the scheme and maintained thereafter in accordance with the scheme. Under no circumstances should any other external lighting be installed without prior written consent from the Local Planning Authority.

**Reason:**

In the interests of the amenities of the area, the site's biodiversity (particularly in respect of bats), the interests of minimising crime, the interests of road safety and to minimise unnecessary light spillage outside the development site in accordance with Arun Local Plan policies QE SP1, QE DM2, T SP1 and ENV DM5.

**CONSHOUR : Hours of working - no CMP**

Demolition/construction works shall only take place between 08:00 hours and 18:00 hours (Monday to Friday) and between 08:00 hours and 13:00 hours on Saturday with no activities taking place on Sundays or recognised public holidays.

In addition to these hours of working, the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition.

**Reason:**

To protect the amenity of local residents in accordance with the Arun Local Plan policy QE SP1.

**PCENV3 : Full PCL condition**

Prior to commencement of the development hereby approved, or such other date or stage in development as may be agreed in writing with the Local Planning Authority, the following components of a scheme to deal with the risks associated with contamination of the site shall be submitted to and approved in writing by the Local Planning Authority:

1. a preliminary risk assessment which has identified all previous uses, potential contaminants associated with those uses, a conceptual site model and potentially unacceptable risks arising from contamination at the site.
2. a site investigation scheme, based on (1) to provide information for a detailed risk assessment of all receptors that may be affected, including those off site.
3. based on (2), an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken. The remediation strategy shall include details of the data that will be collected in order to demonstrate that the proposed remedial works are complete and identify any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.
4. a verification report demonstrating completion of the works set out in the approved submission (3) and the effectiveness of the remediation. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. Where necessary, the report shall also include long-term monitoring and maintenance plans and arrangements for contingency action.

**Note:**

Any changes to these components require the express written consent of the Local Planning Authority.

**Reason:**

To ensure that the development complies with approved details in the interests of protection of the environment and prevention of harm to human health in accordance with the Arun Local Plan policies QE SP1 and QE DM4. This is required to be a pre-commencement condition because these details have to be agreed and in place before any work commences.

## **PCEHN27 : New residential development**

Prior to the commencement of the development, a scheme for protecting the proposed dwellings from noise shall be submitted to and approved in writing by the Local Planning Authority. The proposed scheme shall achieve the following noise levels, based on Table 4 of BS 8233:2014:

- a) internal day time (07.00 hours to 23.00 hours) noise levels shall not exceed 35dB LAeq, 16hr for habitable rooms (bedrooms and living rooms with windows open)
- b) internal night-time (23.00 hours to 07.00 hours) noise levels shall not exceed 30dB LAeq, with individual noise events not exceeding 45dB L<sub>max</sub> no more than 12 times per night (bedrooms windows open).
- c) garden/external amenity spaces should not exceed 50 dB LAeq, 16hr.

If it is predicted that the internal noise levels specified above will not be met with windows open, the proposed mitigation scheme shall assume windows would be kept closed and will specify an alternative ventilation system, to reduce the need for windows to be opened. As a minimum, this should usually consist of a mechanical heat recovery ventilation system with cool air by-pass or equivalent.

Details shall be compiled by a competent acoustician on sound insulation and noise reduction for buildings and shall be submitted to and approved in writing by the Local Planning Authority.

The applicant should review the Planning Noise Advice Document – Sussex, November 2023:

<https://www.arun.gov.uk/download.cfm?doc=docm93jijm4n19846.pdf&ver=24686>.

The agreed noise mitigation measures shall be fully installed/implemented prior to occupation of any of the affected dwellings and permanently retained in good working order.

### **Reason:**

To protect the amenity of local residents in accordance with Arun Local Plan policy QE DM1. This must be a pre-commencement condition because it is necessary to have such mitigation measures in place before the buildings are occupied.

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF  
[www.arun.gov.uk](http://www.arun.gov.uk)

**To register to receive notification of planning applications in your area please go to**  
<https://www1.arun.gov.uk/planning-application-finder>



**From:** chris.white@arun.gov.uk <chris.white@arun.gov.uk>

**Sent:** 14 February 2025 13:33

**To:** Planning.Responses <Planning.Responses@arun.gov.uk>

**Cc:** Chris White <Chris.White@arun.gov.uk>

**Subject:** Planning Response BN-11-25-PIP - Land South Of, Wandleys Lane, Eastergate, West Sussex

## **Planning Response BN-11-25-PIP - Land South Of, Wandleys Lane, Eastergate, West Sussex**

Hi Kathryn,

Please find attached EH planning response for the above application.  
Kind Regards

Chris White  
Environmental Protection Officer, Environmental Health  
Arun District Council

T: 01903 737663  
E: [chris.white@arun.gov.uk](mailto:chris.white@arun.gov.uk)

### **Council Information:**

Environmental Health, Arun Civic Centre, Maltravers Road,  
Littlehampton, West Sussex, BN17 5LF

**T: 01903 737500 - E: [EHPlanningConsultations@arun.gov.uk](mailto:EHPlanningConsultations@arun.gov.uk)**

<http://www.arun.gov.uk>

NLPG UPRN 100062237016

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice: This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

▪