



Arun District Council
Maltravers Road
Littlehampton
BN17 5LF

Your ref
BN/125/25/PL

Our ref
DSA000049967

Date
31st December 2025



Dear Sir/Madam,

Proposal: Construction of 2 No dwellings (C2 Residential Institutions), in association with the Hollies, and associated works. This application affects the setting of a listed building and is in CIL Zone 2 and is CIL Liable as new dwellings.

Site: Land South of The Hollies, 84 Barnham Road, Eastergate, PO22 0ES.

Thank you for your correspondence. Please see our comments below regarding the above planning consultation application.

Development Site is not within Southern Water's Supply Area

The development site is not located within Southern Water's statutory area for water supply services. Please contact Portsmouth Water who are the relevant statutory undertaker.

Tree planting

We have restrictions on the proposed tree planting adjacent to Southern Water sewers, rising mains or water mains. Reference should be made to Southern Water's publication "A Guide to Tree Planting near water Mains and Sewers" (https://www.southernwater.co.uk/media/pddob0vn/ds-tree-planting-guide-1_nwm.pdf) and the Sewerage Sector Guidance (<https://www.water.org.uk/sewerage-sector-guidance-approved-documents/>) with regards to any landscaping proposals and our restrictions and maintenance of tree planting adjacent to sewers, rising mains and water mains.

Condition

In order to protect public apparatus, Southern Water requests that if consent is granted, the following pre commencement condition is attached to the planning permission; The developer must advise the local authority (in consultation with Southern Water) of the landscaping proposals in proximity of public apparatus in order to protect it in accordance with Southern Water's guidance, prior to the commencement of the development.

Connection to public sewer - capacity available desktop study under 50

Southern Water has undertaken a desktop study of the area, and our investigations indicate that Southern Water can facilitate foul sewerage /surface water run off disposal to service the proposed development. Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service:

<https://developerservices.southernwater.co.uk> and please read our New Connections Charging Arrangements documents which are available on our website via the following link:

<https://www.southernwater.co.uk/developing-building/connection-charging-arrangements>

We request that should this planning application receive planning approval, the following informative is attached to the consent: Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to, and approved in writing by the Local Planning Authority in consultation with Southern Water.

Proposed soakaways

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development. No new soakaways should be located within 5 metres of a public or adoptable gravity sewer, rising main or water main.

No Soakaways should be connected to the public surface water sewer.

Rainwater Harvesting

The proposed rainwater harvesting system should be designed, installed and maintained to current British Standards to ensure that measures are in place to protect the public water supply and avoid cross contamination.

Condition

Southern Water requests that the following condition be added to any planning consent; Prior to the commencement of development, details of the rainwater harvesting system including measures to prevent contamination of the water supply and any discharge to public sewers will need to be submitted to and approved by the Local Planning Authority.

Prior to occupation of the development, maintenance responsibilities and regimes for the rainwater harvesting system will need to be submitted to and approved by the Local Planning Authority.

Hierarchy of Building Regulations H3 for disposal of surface water - not yet provided documentation proving compliance

If the applicant has not already provided documentation demonstrating compliance with the surface water hierarchy reflected in part H3 of the Building Regulations, as shown below, we will require this to be provided where surface water is being considered for discharge to our network. Whilst reuse does not strictly form part of this hierarchy, Southern Water would encourage the consideration of reuse for new developments.

- Reuse

- Infiltration
- Watercourse
- Storm Sewer
- Combined Sewer

Guidance on Building Regulations is here: <https://www.gov.uk/government/publications/drainage-and-waste-disposal-approved-document-h>

We would like to engage with you on the design for disposal of surface water for this development at the earliest opportunity and we recommend that civil engineers and landscape architects work together and with Southern Water. In many cases this may negate or reduce the need for network reinforcement and allow earlier completion of the development.

Where a surface water connection to the foul or combined sewer is being considered, this should be agreed by the Lead Local Flood Authority, in consultation with Southern Water.

Condition

We request that should this application receive planning approval, the following condition is attached to the consent: Construction of the development shall not commence until details of the proposed means of surface water run off disposal in accordance with Part H3 of Building Regulations hierarchy as well as acceptable discharge points, rates and volumes have been agreed by the Lead Local Flood Authority, in consultation with Southern Water.


S106 Connection application

Any new connections to the public sewerage system will require a Section 106 connection application to be submitted and approved by Southern Water Services. Please note that, where there are separate systems available Southern Water will not allow surface water to connect into the public foul sewer. If this is not possible, please provide evidence that all other options have been explored.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX [REDACTED]

Website: southernwater.co.uk or by email at: [REDACTED]

Yours faithfully,
Future Growth Planning Team
southernwater.co.uk/developing-building/planning-your-development



| | | | | | |
|----------------------------|-----------------------------|-------------------------|------------------------|---------------------------|-----------------|
| Controllable Valve | | Flow Control | | Inlet-Outfall | |
| Damboards | Penstock | Valve | Anti Flood Device | Pumped Anti Flood Device | Reflux Valve |
| Manhole | | | | | |
| BIF Bifurcation | Cascade | CP Catchpit | Head Of Public Sewer | IC Interceptor Chamber | Manhole |
| Soakaway | WO Washout | | | | |
| Outfall Headworks | | Overflow Chamber | | Pipe Bridge | |
| Outfall Headworks | CSO Combined Sewer Overflow | EMO Emergency Overflow | Pipe Bridge | Micro Pumping Station | Pumping Station |
| Sewer Level Monitor | | Storage | | Treatment Works | |
| Sewer Level Monitor | Storm Tank | Tidal Storage Tank | Treatment Works | Weir | Wastewater Site |
| Wastewater Pipe | | Wastewater Use | | Developer Services | |
| Culverted Water Course | Syphon | Foul | Build Over Agreement | Section 104 | |
| Drain | Tank Sewer | Combined | Wastewater Area | | |
| Outfall | Trunk Sewer | Sludge | Catchment | | |
| Overflow | Vacuum Main | Treated Effluent | Sub-Catchment | | |
| Rising Main | Decommissioned Pipe | Surface Water | | | |
| Sewer | | Private | | | |

Map Title: SW Print

Printed By: Anne.McFarlane2
 Date Printed: 31/12/2025
 Map Scale: 750

The information provided is believed to be correct but is provided on an 'as is' basis and without any warranty or condition express or implied, statutory or otherwise as to its quality or fitness for purpose. Actual positions of assets should always be determined on site.



PL- Consultation- Southern Water response



Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>



Our priorities...

| | | | | |
|--|---|---|--|--|
|  <p>Improving the wellbeing of Arun</p> |  <p>Delivering the right homes in the right places</p> |  <p>Supporting our environment to support us</p> |  <p>Fulfilling Arun's economic potential</p> |   |
|--|---|---|--|--|

From: SouthernWater PlanningConsultations

Sent: 31 December 2025 10:52

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: BN/125/25/PL - SWS Planning response - DSA000049967

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Good morning,

Please find attached Southern Waters' response for this application.

Yours
faithfully,

Anne McFarlane
Future Growth Planning
Developer Services


southernwater.co.uk



This e-mail is intended solely for the person or organisation to which it is addressed. It may contain privileged and confidential information. If you are not the intended recipient, you are prohibited from copying, disclosing or distributing this e-mail or its contents (as it may be unlawful for you to do so) or taking any action in reliance on it.

If you receive this e-mail by mistake, please delete it then advise the sender immediately.

Without prejudice to the above prohibition on unauthorised copying and disclosure of this e-mail or its contents, it is your responsibility to ensure that any onward transmission, opening or use of this message and any attachments will not adversely affect your or the onward recipients' systems or data. Please carry out such virus and other such checks as you consider appropriate.

An e-mail reply to this address may be subject to monitoring for operational reasons or lawful business practices

This e-mail is issued by Southern Water Services Limited, company number 2366670, registered in England and having its registered office at Southern House, Yeoman Road, Worthing, BN13 3NX, England.

In sending this e-mail the sender cannot be deemed to have specified authority and the contents of the e-mail will have no contractual effect unless (in either case) it is otherwise agreed between Southern Water Services Limited and the recipient.