

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter **[here](#)**



From: Joanne Lewis <Joanne.Lewis@arun.gov.uk>
Sent: 01 October 2021 14:29
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: BN/126/21/DOC

I refer to the above application for discharge of conditions and make the following recommendations;

5 – noise

Condition may be discharged.

11 - electric vehicle charging

The location of the charger is acceptable but detail should be provided on the type of charger to be installed before discharge of this condition can be recommended. Chargers should be Mode 3, 7kw fast chargers as a minimum.

Joanne Lewis

Please note that I work part time, usually between 09.30 and 14.45 Tuesday – Friday.

Joanne Lewis
Senior Environmental Health Officer,
Environmental Health



T: 01903 737666
E: joanne.lewis@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

I occasionally send emails outside of working hours. If this arrives outside your normal working hours, please do not feel compelled to respond immediately.

Sign up to our newsletter [here](#)



Business Support during Coronavirus click [here](#)

From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 28 September 2021 09:19

To: EHPlanningConsultations [REDACTED]

Subject: Planning Consultation on: BN/126/21/DOC

To: **Environmental Health - Planning consultation**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: BN/126/21/DOC

Registered: 27th September 2021

Site Address: Tile Barn Farm 32 Hill Lane Barnham PO22 0BL

Description of Works: Approval of details reserved by condition imposed under ref W/4001228 (BN/24/20/PL) relating to Condition Nos 3 - materials and finishes, 5 - noise, 6 - dustbin enclosure, 7 - renewable energy, 10 - covered & secure cycle parking, 11 - electric vehicle charging, 12 - surface water drainage and 13 - foul drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **12th October 2021**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Amy Myer

Planning Case Officer- Arun District Council

Telephone: 01903 737776

Email: amy.myer@arun.gov.uk

PLCOND00 (ODE) 2020