

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 12 October 2021 09:16
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: RE: Planning Consultation on: BN/127/21/DOC

Comments Regarding Condition 3

Please supply as built drawings.

Please detail if a CCTV survey has been completed of the piped network.

Please supply a full list of dates of inspections completed as part of the verification process.

Please supply evidence that the appropriate flow control devices have been installed as per the design.

Comments Regarding Condition 5

We cannot recommend discharge of this condition until further verification information has been supplied.

Please reconsult us once further information has been supplied.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 28 September 2021 08:49

To: Land Drainage

Subject: Planning Consultation on: BN/127/21/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: BN/127/21/DOC

Registered: 27th September 2021

Site Address: Land At Angels Nursery Yapton Road Barnham PO22 0AY

Description of Works: Approval of details reserved by condition imposed under BE/84/20/PL relating to conditions 3-as built drawings of implemented SuDS scheme & 5-updated copy of management manual or confirmation that no changes are required to manual.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **12th October 2021**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Michael Eastham

Planning Case Officer- Arun District Council

Telephone: 01903 737772

Email: michael.eastham@arun.gov.uk

PLCOUNDOC (CDE) 2020