

## Environmental Health Consultation Response

<b>To</b>	Mr S Davis
<b>Date</b>	05-11-2024
<b>Planning Ref</b>	BN/128/24/RES
<b>Site Description</b>	Eastmere Stables Eastergate Lane Eastergate West Sussex
<b>Date of Application</b>	2024-10-08 00:00:00
<b>Category</b>	Reserved Matters
<b>Recommendation</b>	No Objection  No Objection – with conditions  Objection  Holding Objection

### EH Comments:

The applicant has submitted documents that relate to Construction Management Plan and Electric vehicle charging points and I am happy with the information provided.

I would then still echo my colleagues previous comments from the outline application BN/99/22/OUT regarding the below conditions.

### Conditions Recommended:

I refer to the above planning application and make the following comments;

### Contaminated Land

Prior to commencement of the development hereby approved (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved in writing by the Local Planning Authority:

1. A 'Preliminary Risk Assessment' which has identified: all previous (historical) uses; potential contaminants associated with those uses; a conceptual model of the site indicating sources, pathways and receptors; and potentially unacceptable risks arising from contamination at the site.
2. A 'Site Investigation Scheme', based on (1) above to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
3. Based on the 'Site Investigation Scheme' and the detailed risk assessment (2), an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
4. A 'Verification Report' providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Note: Any changes to these components, (1) to (4) require the express written consent of the Local Planning Authority.

The scheme shall be implemented as approved above and, prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a Verification Report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of that remediation shall be submitted to and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. The report shall also include a 'long-term monitoring and maintenance plan' for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification report, and for the reporting of this in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

**Lighting - the following condition should be applied to any permission granted;**

Details of the proposed lighting scheme for the development shall be provided and approved by the Local Planning Authority before installation.

Due to the relative proximity of existing residential premises there is the potential for the development to cause a loss of amenity as a result of light glare / creep / bleed.

Light intrusion into residential windows shall not exceed 10 Lux between 07:00 and 21:00 hours and 5 Lux between 21:00 and 07:00 hours, measured as Vertical Illuminance (EV) normal to glazing. The Sky Glow (Upward Light Ratio) shall not exceed 5.0%

Prior to the commencement of the development, details of the external lighting of the site shall be submitted to and approved in writing by the Local Planning Authority. These details shall include the predictions of both horizontal illuminance across the site and vertical illuminance affecting immediately adjacent receptors. The lighting installation shall comply with the recommendations of the Institution of Lighting Professionals (ILP) "Guidance Notes for the Reduction of Obtrusive Light" (GN01:2011)

Prior to occupation, the predicted illuminance levels shall be tested by a competent person to ensure that the illuminance levels agreed in the scheme are achieved. Where these levels have not been met, a report shall demonstrate what measures have been taken to reduce the levels to those agreed within the application scheme.

The approved installation shall be maintained and operated in accordance with the approved details unless the Local Planning Authority gives its written consent to a variation.

Reason: To protect the amenity of local residents in accordance with Policy QE DM2 of the Adopted Arun Local Plan 2011 – 2031

**Noise –The following condition should therefore be applied to any permission granted to ensure that a suitable noise assessment is carried out;**

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the "Indoor ambient noise levels for dwellings" guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014.

Details shall be compiled by a competent acoustician on sound insulation and noise reduction for buildings and shall be submitted to and approved in writing by the Local Planning Authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

## **Informative**

The granting of this planning permission does not in any way indemnify against statutory nuisance action being taken should substantiated complaints within the remit of the Environmental Protection Act 1990 be received. For further information please contact the Environmental Health Department on (01903) 737555

Arun District Council, Civic Centre, Maltravers Rd  
Littlehampton, West Sussex, BN17 5LF  
[www.arun.gov.uk](http://www.arun.gov.uk)

To register to receive notifications of planning applications in your area please go to  
<https://www1.arun.gov.uk/planning-application-finder>



**Sent:** 05 November 2024 17:37

**To:** Planning.Responses <Planning.Responses@arun.gov.uk>

**Cc:** Chris White [REDACTED]

**Subject:** Planning Response BN-128-24-RES - Eastmere Stables, Eastergate Lane, Eastergate, West Sussex

## Planning Response BN-128-24-RES - Eastmere Stables, Eastergate Lane, Eastergate, West Sussex

Hi Simon,

Please find attached EH planning response for the above application..  
Kind Regards

Chris White  
Environmental Protection Officer, Environmental Health



### **Council Information:**

Environmental Health, Arun Civic Centre, Maltravers Road,  
Littlehampton, West Sussex, BN17 5LF

**T: 01903 737500 -** [Redacted]

<http://www.arun.gov.uk>  
NLPG UPRN 100062237016  
DX 57406 Littlehampton  
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

**Important Notice:** This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.