

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Ian Stocks [REDACTED] **On Behalf Of** FRS Water and Access
Sent: 17 March 2022 13:34
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: Planning consultation - BN/12/22/PL St Philip Howard School Elm Grove South Barnham PO22 0EN

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

FAO: Amber Willard

Dear Amber,


Having viewed the plans for planning application BN/12/22/PL evidence is required to show access for a fire appliance to whichever is the less onerous; 15% of the perimeter of the new block or within 45 metres of every point of the footprint of the building in accordance with the requirements identified in Approved Document – B (AD-B) Volume 2 2019 edition: B5 section 15. From the plans submitted there does not appear to be any access for a fire appliance to this block.

Regards

Ian

Ian Stocks – Water and Access Manager
Water and Access Office
West Sussex Fire and Rescue Service [West Sussex County Council](#)

Living Our Values Every Day



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
