


To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter **[here](#)**




Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter **[here](#)**





From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>

Sent: 17 August 2021 11:04

To: James Cross <James.Cross@arun.gov.uk>

Cc: Roger Spencer <Roger.Spencer@arun.gov.uk>; Laura Gibbons <Laura.Gibbons@arun.gov.uk>; Paul Cann <Paul.Cann@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: RE: BN/135/20/PL - Boweries, Barnham Road, Barnham

Hi James,

It has come to my attention that I missed a reference to surface water pumping on the proposed Drainage Strategy. Pumping surface water is not sustainable and is in contradiction of the adopted WSCC Policy for the Management of Surface Water. Therefore it is suggested that the applicant supplies a revised indicative strategy which shows that it is possible to drain surface water from the site without the use of a pump.

In order to do this it may be necessary to supply topographical levels of the watercourse on the south boundary (as the topographical levels rise at the south of the site, assumably before dropping again – not shown). Until we have evidence to show that no surface water pumps will be used on the site I will need to alter my consultation response to a **holding objection**. All my previous comments (below) still stand.

I wish to offer my sincere apologies for not noticing this detail earlier and for any inconvenience or delay that is caused to yourself and the applicant as result.

Kind regards

Sarah Burrow
Engineering Assistant, Engineering Services

T: 01903 737815

E: sarah.burrow@arun.gov.uk



Current working pattern: Monday 8am-2:30pm, Tuesday 8am-5:30pm, Wednesday 8am-5pm, Thursday 8am-5:30pm, Friday 8am-11:30am.

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

