



From: Paul Cann <Paul.Cann@arun.gov.uk>
Sent: 22 November 2021 10:20
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: BN/142/21/PL

Comments on proposed surface water drainage

The applicant has not supplied any information regarding a proposed surface water drainage scheme.

The hierarchy for sustainable drainage must be followed with infiltration fully investigated. Due to the existing mature tree at the rear of the property, and taking account of its potential root protection zone, in which drainage must not be installed and the need to ensure infiltration structures are at least 5 metres from proposed/existing structures, there would appear to be very little room available to accommodate a suitable drainage scheme. The development may also impact on any infiltration structures/soakaways that serve the existing property, so this aspect will need to be duly considered too.

It is essential to establish if there is adequate space for an acceptable surface water drainage scheme prior to agreement of the site layout. Drainage should be a fundamental consideration in design. Failure to secure a robustly evidenced implementable drainage strategy at this stage will likely unduly prejudice the drainage design and result in proposals failing to meet policy requirements.

As a result of the above, I object to the application, until such time that it can be proven that a satisfactory drainage scheme can be accommodated.

However, If you are minded to approve the application then please apply the following condition to ensure that the development is adequately drained and does not increase flood risk elsewhere. Please also note that it is unclear at this stage as to whether condition **PCENG D2** can be met based upon the current development layout and the uncertainty over the form in which the surface water drainage scheme will ultimately take.

PCENG D2

"Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity."

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

And the accompanying informative:

INFORM D

"Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 40% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location. Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers."

Supplementary guidance notes regarding surface water drainage are located here

<https://www.arun.gov.uk/surfacewater> on Arun District Councils website. A surface water drainage checklist is available on Arun District Councils website, this should be submitted with a Discharge of Conditions Application."

Regards

Paul Cann
Principal Drainage Engineer
Engineering Services

T: 01903 737819
E: paul.cann@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: Tuesday, November 9, 2021 8:33:49 AM (UTC+00:00) Monrovia, Reykjavik
To: Land Drainage <Land.Drainage@arun.gov.uk>
Subject: Planning Consultation on: BN/142/21/PL

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

Application No: BN/142/21/PL
Registered: 9th November 2021
Site Address: 1 Como Barnham Road Eastergate PO20 3RT
Grid Reference: 494990 105301
Description of Works: Erection of a new two-storey building to contain 2 No 2 bedroom flats with associated parking, bin and bike stores and landscaping. This site is in CIL Zone 2 and is CIL Liable as new flats.

The Council have received the above application.

[Click here to view the application details](#)

This application has been identified as CIL Liable. Therefore please be aware that, in accordance with Appendix 2 of the Arun CIL Charging Schedule, your consultation response should only include requests for Section 106 for onsite mitigation, Pagham Harbour Management Contributions (if applicable) or Affordable Housing. "Off" Site mitigation measures directly related to this development should be dealt with by condition if possible to ensure the scaling back of Section 106 if possible. CIL contributions will be used for "off" site infrastructure mitigation schemes. Therefore if this proposal triggers the need for "off" site mitigation, please ensure that you engage in the CIL Infrastructure List Consultation process upon receipt of a consultation letter.

Should you have any comments to make, these should be sent by replying to this email by 9th December 2021. You can also monitor the progress of this application through the Council web site:

<https://www.arun.gov.uk/planning-application-search>

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website

<https://www.arun.gov.uk/development-plan> as can information on what comments we can consider
<https://www.arun.gov.uk/planning-application-comments>

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://acp.planninginspectorate.gov.uk/> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Maria Tomalova

Planning Officer- Arun District Council

Telephone: 01903 737510

Email: maria.tomalova@arun.gov.uk

PLCONSULT (008) 2020