

WEST SUSSEX COUNTY COUNCIL CONSULTATION

TO:	Arun District Council FAO: Maria Tomalova
FROM:	WSCC - Highways Authority
DATE:	24 February 2021
LOCATION:	Land at Chantry Mead & Rear of 14 -18 Downview Road Barnham PO22 0EG
SUBJECT:	BN/150/20/PL 3 No dwellings including access, landscaping & associated works (resubmission following BN/51/20/PL). This site is in CIL Zone 2 and is CIL Liable as new dwellings.
DATE OF SITE VISIT:	n/a
RECOMMENDATION:	Advice
S106 CONTRIBUTION TOTAL:	n/a

This application has been dealt with in accordance with the Development Control Scheme protocol for small scale proposals which include up to 5 residential units or extensions to single units accessed from roads that do not form part of the Strategic Road Network (SRN). As such the comments provided by Planning Services should be considered to be advice only, with respect to this planning application.

This proposal has been considered by means of a desktop study, using the information and plans submitted with this application, in conjunction with other available WSCC map information. A site visit can be arranged on request.

I refer to your consultation in respect of the above planning application and would provide the following comments.

The development is located on a private road and at a distances from any publicly maintainable highway. Any parking provisions on the site are to be considered an amenity issue and therefore, to be considered by the Local Planning Authority and not the Local Highways Authority.

The applicant has proposed a NIL cycle parking provision, the LHA advises the Local Planning Authority (LPA) that if they deem cycle parking justifiable then the applicant should show this in the form of lockable covered storage. Details of which can be secured with a suitably worded condition found below.

In the interests of sustainability and as result of the Government's 'Road to Zero' strategy for at least 50% of new car sales to be ultra-low emission by 2030, electric vehicle (EV) charging points should be provided for all new homes. The applicant is advised that for dwellings with a garage or driveway, 100% of parking spaces should be provided with active EV parking spaces in accordance with the Arun Parking Standards (adopted January 2020). Details of this can be secured via condition and a suitably worded condition is advised below.

Conclusion

The LHA does not consider that this proposal would have an unacceptable impact on highway safety or result in 'severe' cumulative impacts on the operation of the highway

network, therefore is not contrary to the National Planning Policy Framework (paragraph 109), and that there are no transport grounds to resist the proposal.

The LHA advises the LPA that if they are mindful to permit the above application than to attach the following conditions and informative:

Cycle Parking

No part of the development shall be first occupied until covered and secure cycle parking spaces have been provided in accordance with plans and details **to be** submitted to and approved by the Local Planning Authority.

Reason: To provide alternative travel options to the use of the car in accordance with current sustainable transport policies.

Electric Vehicle Charging Spaces

No part of the development shall be first occupied until the electric vehicle charging space(s) have been provided in accordance with plans and details **to be** submitted to and approved by the Local Planning Authority.

Reason: To provide sustainable travel options in accordance with current sustainable transport policies.

Stephen Garrard
West Sussex County Council – Planning Services