

**From:** Amanda Scholes on behalf of Planning.Responses  
**Sent:** 08 February 2021 08:37  
**To:** Planning Scanning  
**Subject:** FW: Planning Consultation on: BN/151/20/PL

**Amanda Scholes**

**T:** 01903 737453  
**E:** amanda.scholes@arun.gov.uk



**To register to receive notification of planning applications in your area please go to**  
**[www.arun.gov.uk/planning](http://www.arun.gov.uk/planning)**

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF  
**[www.arun.gov.uk](http://www.arun.gov.uk)**

Sign up to our newsletter **[here](#)**



---

**From:** Sarah Burrow <Sarah.Burrow@arun.gov.uk>  
**Sent:** 08 February 2021 08:29  
**To:** Planning.Responses <Planning.Responses@arun.gov.uk>  
**Cc:** Maria Tomalova <Maria.Tomalova@arun.gov.uk>  
**Subject:** RE: Planning Consultation on: BN/151/20/PL

#### Engineers Comments Regarding Surface Water Drainage

The application is within the Lidsey Treatment Catchment, therefore surface water drainage design should be carefully considered. Infiltration must be fully investigated. A General Drainage Specifications/Layout has been provided, however it appears that no infiltration testing or groundwater monitoring has been undertaken to inform the detailed design. No detailed design, calculations or construction details have been supplied at this stage.

If you are minded to approve the application please apply the following conditions to ensure that the development is adequately drained and does not increase flood risk elsewhere.

#### **PCENG D2**

*"Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage*

system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity."

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

And the accompanying informative:

#### INFORMD

*"Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 40% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location. Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers.*

Supplementary guidance notes regarding surface water drainage are located here

<https://www.arun.gov.uk/surfacewater> on Arun District Councils website. A surface water drainage checklist is available on Arun District Councils website, this should be submitted with a Discharge of Conditions Application."

Kind Regards

**Sarah Burrow**

Engineering Assistant, Engineering Services

T: 01903 737815

E: [sarah.burrow@arun.gov.uk](mailto:sarah.burrow@arun.gov.uk)



Whilst national restrictions are in place I will be working flexibly between the hours of 8am and 8pm. I appreciate your patience if I am slower than usual to respond. Equally I understand that you may be facing similar challenges and varying work patterns and will not be expecting immediate responses to my e-mails.

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

[www.arun.gov.uk](http://www.arun.gov.uk)

Sign up to our newsletter [here](#)



---

**From:** Planning.Responses <[Planning.Responses@arun.gov.uk](mailto:Planning.Responses@arun.gov.uk)>

**Sent:** 15 December 2020 14:20

**To:** Land Drainage <[Land.Drainage@arun.gov.uk](mailto:Land.Drainage@arun.gov.uk)>

**Subject:** Planning Consultation on: BN/151/20/PL

To: **Engineers (Drainage)**

**NOTIFICATION FROM ARUN DISTRICT COUNCIL**

**Town & Country Planning Act 1990 (as amended)**

**Town and Country Planning (Development Management Procedure) (England) Order 2015**

**Planning Permission**

**Application No:** BN/151/20/PL  
**Registered:** 14th December 2020  
**Site Address:** Land at rear of Poachers Eastergate Lane Eastergate PO20 3SJ  
**Grid Reference:** 494870 106097  
**Description of Works:** Erection of 1 No. 4 bedroom detached dwelling with detached carport (resubmission following BN/46/20/PL). This site is in CIL Zone 3 & is CIL Liable as new dwelling & is a Departure from the Development Plan.

The Council have received the above application.

[Click here to view the application details](#)

This application has been identified as CIL Liable. Therefore please be aware that, in accordance with Appendix 2 of the Arun CIL Charging Schedule, your consultation response should only include requests for Section 106 for onsite mitigation, Pagham Harbour Management Contributions (if applicable) or Affordable Housing. Off Site mitigation measures directly related to this development should be dealt with by condition if possible to ensure the scaling back of Section 106 if possible. CIL contributions will be used for off site infrastructure mitigation schemes. Therefore if this proposal triggers the need for off site mitigation, please ensure that you engage in the CIL Infrastructure List Consultation process upon receipt of a consultation letter.

Should you have any comments to make, these should be sent by replying to this email by 28th January 2021 . You can also monitor the progress of this application through the Council web site:

[www.arun.gov.uk/planning](http://www.arun.gov.uk/planning).

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website <https://www.arun.gov.uk/development-plan> as can the the leaflet how to respond to planning applications <https://www.arun.gov.uk/planning-application-comments> which deals with material planning considerations.

**Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.**

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://www.planningportal.co.uk/info/200207/appeals> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Maria Tomalova

Planning Officer- Arun District Council

Telephone: 01903 737510

Email: [maria.tomalova@arun.gov.uk](mailto:maria.tomalova@arun.gov.uk)

