

Simon Davis

From: Nathan Chilvers <[REDACTED]>
Sent: 17 December 2021 16:13
To: Simon Davis
Cc: Adrian Bristow
Subject: RE: 0412 - RE: BN/160/21/NMA Tars Farm

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Simon,

Please remove the resin bound surfacing as one of the amendments covered by the application.

Thanks,

Nathan Chilvers BA(Hons) Dip Arch ARB | Project Director
For and on behalf of **Mohsin Cooper Limited**

**mohsin
cooper**

[Email](#) [Website](#) [LinkedIn](#) [Twitter](#) [Instagram](#)

Architecture + Planning

Mohsin Cooper Limited. Registered in England and Wales. Company Registration Number: 7287902. Registered Address: 16 West Barnes Lane, London, SW20 0BU.

The contents of this email and any attachments are intended for and confidential to the addressee. They should not be communicated to, or relied upon, by any other party without our written consent. If you are neither the addressee nor an authorized recipient from the addressee please notify us of receipt, delete this message from your system, and do not use copy or disseminate the information in or attached to it in any way. Any files attached to this e-mail will have been checked with virus detection software prior to transmission, but you should carry out your own virus check before opening any attachment. Mohsin Cooper Ltd does not accept liability for any loss or damage which may be caused by software viruses.

From: Simon Davis <Simon.Davis@arun.gov.uk>
Sent: 17 December 2021 16:07
To: Nathan Chilvers <[REDACTED]>
Cc: Adrian Bristow <[REDACTED]>
Subject: RE: 0412 - RE: BN/160/21/NMA Tars Farm

Dear Nathan.

Thanks for this. However, if your client wishes to revert back to what has been approved then there is no need for this Non-Material Amendment application and so you should instead withdraw this application. Please respond to confirm that you agree to the withdrawal and I will action.

Kind Regards

Simon J Davis MRTPI
Principal Planning Officer
Directorate of Place



T: 01903 737874
E: simon.davis@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil

Sign up to our newsletter [here](#)  



From: Nathan Chilvers <[REDACTED]>
Sent: 16 December 2021 14:51
To: Simon Davis <Simon.Davis@arun.gov.uk>
Cc: Adrian Bristow <[REDACTED]>
Subject: 0412 - RE: BN/160/21/NMA Tars Farm

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Simon,

Please see attached revised drawing.


The client is happier with block paving (over resin bound) as originally consented I believe.

I trust this is all you need from us? Please let us know if not.

Kind regards,

Nathan Chilvers BA(Hons) Dip Arch ARB | Project Director
For and on behalf of **Mohsin Cooper Limited**

**mohsin
cooper**



[Email](#) [Website](#) [LinkedIn](#) [Twitter](#) [Instagram](#)