-----Original Message-----
From: William Bolland [redacted]
To: Phil Faulkner [redacted]
CC: Paul Cann [redacted] Vince Carpenter
[redacted]>; Jon Lord [redacted] Andrew Martin
[redacted]
Sent: Wed, 9 Feb 2022 10:30
Subject: Re: Barnham Court - Drainage

Thank you gentlemen ,
This is noted and we will finish this work tomorrow as per these revised specifications.
When finished we will forward record of pictures of work in progress and when finished.

Kind regards,

William Bolland

On 9 Feb 2022, at 10:08, Phil Faulkner [redacted] wrote:

Paul

Further to our telephone conversation this morning, I confirm your acceptance that the proposed concrete bagwork can be omitted from the base of the existing ditch at the outfall structure.

The concrete bagwork will be placed besides the outfall to the bank face only. The client will provide photographs of the installed outfall.

As noted on our drawings the bagwork will be pinned together and will not extend into the existing ditch.

Regards

Phil Faulkner EngTech MICE
Project Engineer
Archibald Shaw
One Little London
Chichester
West Sussex
PO19 1PP

[redacted]

This email and any attachments are confidential to the intended recipient only and may also be privileged. If you have received it in error please delete it from your system and notify the sender.

The copyrights of all attached files on this email are the property of Archibald Shaw LLP and may only be used in connection with the project for which it was prepared.

Registered in England. Registered Office: Archibald Shaw LLP One Little London, Chichester PO19 1PP. Reg No. 0C310866