On 22 Dec 2021, at 15:23, Phil Faulkner [redacted] wrote:

Paul

Many Thanks.

Have a good Christmas

Phil Faulkner EngTech MICE

Project Engineer

Archibald Shaw

One Little London

Chichester

West Sussex

PO19 1PP

[redacted]

Click here...

This email and any attachments are confidential to the intended recipient only and may also be privileged. If you have received it in error please delete it from your system and notify the sender.

The copyrights of all attached files on this email are the property of Archibald Shaw LLP and may only be used in connection with the project for which it was prepared.

Registered in England. Registered Office: Archibald Shaw LLP One Little London, Chichester PO19 1PP. Reg No. 0C310866

From: Paul Cann <[redacted]
Sent: 22 December 2021 15:20
To: Phil Faulkner <[redacted]
Cc: William Bolland [redacted]; Jon Lord <[redacted]; Vince Carpenter [redacted]
Subject: RE: Barnham Court - Surface Water Drainage

Phil

All noted.

Land drainage consent enclosed (please forward photos of the headwall once complete).

We will await Vince's report to confirm that the entire surface water drainage has been installed as per the drawings (obviously once construction is finished). Then I would suggest everything is submitted through planning to discharge the relevant planning condition.

Regards

Paul Cann

Principal Drainage Engineer

[redacted]

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter **here**

From: Phil Faulkner [redacted]
Sent: 22 December 2021 14:42
To: Paul Cann [redacted]
Cc: William Bolland [redacted] Jon Lord [redacted] Vince Carpenter [redacted]
Subject: FW: Barnham Court - Surface Water Drainage

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Paul

Please find below confirmation that guttering on both sides of the pitched roofs will drain to the proposed water butts for both the new Gardeners Hut and The Garage.

Appropriate size orifice plates will need to be installed in the water butt outlets.

I trust that all is now in place for you to approve the scheme and give Land Drainage Consent. Approval before the Christmas break would be much appreciated.

Regards

Phil Faulkner EngTech MICE

Project Engineer

Archibald Shaw

One Little London

Chichester

West Sussex

PO19 1PP



This email and any attachments are confidential to the intended recipient only and may also be privileged. If you have received it in error please delete it from your system and notify the sender.

The copyrights of all attached files on this email are the property of Archibald Shaw LLP and may only be used in connection with the project for which it was prepared.

Registered in England. Registered Office: Archibald Shaw LLP One Little London, Chichester PO19 1PP. Reg No. 0C310866