

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: David Spring <David.Spring@arun.gov.uk>
Sent: 04 May 2020 16:39
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: Cherrytrees BN/21/20/PL

Hi,

Please add the e mail below from Drainage to the above application.

With thanks,

David Spring B.Sc, M.Sc, M.A

Senior Planner (Agency)

Arun District Council, Maltravers Road, Littlehampton, BN17 5LF

Email: David.Spring@arun.gov.uk | DD: 01903 737521

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil

From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>
Sent: 04 May 2020 16:35
To: David Spring <David.Spring@arun.gov.uk>
Subject: RE: Cherrytrees BN/21/20/PL

Hi David,

OK that's fine. Please disregard my request for the condition to be applied. The surface water drainage design should be constructed in accordance with Drainage Drawing 3A and the corresponding technical information provided previously should the application be approved.

Kind Regards

Sarah Burrow
Engineering Assistant

From: David Spring <David.Spring@arun.gov.uk>
Sent: 04 May 2020 09:28
To: Sarah Burrow <Sarah.Burrow@arun.gov.uk>
Subject: FW: Cherrytrees BN/21/20/PL

Good Morning Sarah,

Please see the attached and the email below.

With thanks,

David Spring B.Sc, M.Sc, M.A

Senior Planner (Agency)

Arun District Council, Maltravers Road, Littlehampton, BN17 5LF

Email: David.Spring@arun.gov.uk | DD: 01903 737521

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil

From: John Baldwinson [REDACTED]
Sent: 02 May 2020 14:44
To: David Spring <David.Spring@arun.gov.uk>
Subject: Fw: Cherrytrees BN/21/20/PL

Hi David

We have amended the drainage as requested and attached.

1 All drains will be surrounded in 150 concrete, noted and detailed.

2 The soakaways will be located under raised beds to provide the cover needed, this will also give a visible, protected location for the soakaways for the future. Noted and detailed

3 The drive and parking areas will be constructed as the existing, permeable hardcore base with gravel finish to be self draining, noted on the drawing.

Finally we agree to an extension of time to the 15th May

Stay Safe
John Baldwinson