

Amber Willard

From: stephen jupp [REDACTED]
Sent: 05 June 2019
To: Amber Willard
Cc: Danny Keet
Subject: Re: bn/22/19/pl

Follow Up Flag: Follow up
Flag Status: Flagged

Amber

I can confirm that we will change the sub-base to Type 3 and the topping will be limestone chippings or similar with a min void ratio of 30%.

Kind regards

Steve Jupp

Stephen Jupp MRTPI
Chartered Town Planner
Sally Field Lodge
Rotten Row
Sidlesham
West Sussex
PO20 7QB

[REDACTED]

On 4 Jun 2019, at 09:54, Amber Willard <[REDACTED]>

Dear Mr Jupp,