

From: Amanda Scholes on behalf of Planning.Responses
Sent: 22 May 2019 08:47
To: Planning Scanning
Subject: FW: Planning Consultation on BN/26/19/DOC

From: Laura Gibbons
Sent: 22 May 2019 08:46
To: Planning.Responses
Cc: Stuart Corbey
Subject: RE: Planning Consultation on BN/26/19/DOC

Engineers Comments Regarding Condition 4- surface water drainage

Please can more detail be submitted regarding infiltration testing completed. It is stated that an average is used because of the difference in results obtained at different depths. We would expect the worst case rate found at the proposed depth of the infiltrating structure to be used in design.

Please can the applicant also provide a factor of safety of 3 rather than 2.

I will review further on the submission of further information.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: [planning.responses](#)
Sent: 15 May 2019 11:24
To: Land Drainage
Subject: Planning Consultation on BN/26/19/DOC

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION BN/26/19/DOC

NO:

Registered: 02-MAY-19
Site Address: Flintstones Barnham Road Eastergate PO20 3RT
Description of Works: Approval of details reserved by condition imposed under ref EG/66/18/HH relating to Condition Nos 3 - foul water drainage and 4 - surface water drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 29th May 2019.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Stuart Corbey who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_cor_email
