

RPS Design Group Ltd
3 The Mount
Whitchurch
SY13 1GX

Date: 5th May 2022

Please ask for: Amber Willard

Tel: 01903 737500 x37445

Your Ref:

Our Ref: BN/28/22/DOC

Dear Mr James,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under BN/114/21/PL relating to conditions 3-schedule of materials and finishes, 4-renewable energy, 6-Construction Management Plan, 8-bin storage, 10-covered and secure cycle parking spaces, 11-electric vehicle charging points, 12-surface water drainage, 13-foul water drainage and 17-external lighting.

Land the rear of Hlghground House and Orchard End Barnham

Notification regarding the above application:

Condition Number 12

Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to agree and implement the surface water drainage system prior to commencing any building works.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**

Drainage were consulted and recommended the condition is discharged.

All surface water drainage should be constructed in accordance with the following drawings:

Drainage Layout C1931 P 100 P1

Drainage Details C1931 P 200 P- (In surface water drainage report)

The condition is discharged in accordance with the above documents subject to construction in accordance with the approved documents.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning