

Mrs June Grinstead
Chichester Enterprise Centre
Terminus Road
Chichester
PO19 8TX

Date: 23rd February 2021

Please ask for: Finlay Gardner

Tel: 01903 737915

Your Ref:

Our Ref: BN/2/21/DOC

Dear Mrs Grinstead,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under BN/130/19/HH relating to condition 3-surface water drainage.

Flamsteed Lake Lane Barnham PO22 0AD

Notification regarding the above application:

Condition Number 3

Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**

The Council's Drainage Engineers have been consulted and the details submitted are considered to meet the aims and requirements of the condition.

The approved details are hereby:

- Drainage Statement
- Pillar Tank Details
- Ultra Low Discharge Flow Control
- Rain Acti Maintenance Schedule
- Floor Plan/Elevations Attenuation Information
- Supply of Rain Water Harvesting Equipment
- Email from agent dated 15-2-2021

The condition is therefore fully discharged insofar as the submission of details relates and on the understanding that the surface water drainage scheme will be implemented in accordance with the approved scheme and permanently retained in good working order thereafter.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning