

From: Amanda Scholes on behalf of Planning.Responses
Sent: 01 April 2021 08:32
To: Planning Scanning
Subject: FW: BN/30/21/DOC 2 Bungalows-Canal Mews-Barnham Condition 8 (EV Charging)

Essential maintenance is being carried out to the planning, building control and local land charges database during the week commencing 12 April 2021.

During this time there will be no public or staff access to any records held within this database, and it will not be possible to carry out any of the following tasks via the Arun website:

- Research planning and building control history
- View any planning applications, plans, agreements, tree preservation orders or competent persons data
- Submit building control applications
- Submit planning application comments
- Report any planning compliance issues

The publicity and consultation period for all planning applications that fall over this week will be extended by a further week to ensure no one is disadvantaged.

All other aspects of planning, building control and local land charges will be limited during this week and you are strongly advised to contact the individual departments before 12 April 2021 for specific restrictions during this time.

Amanda Scholes

T: 01903 737453

E: amanda.scholes@arun.gov.uk



To register to receive notification of planning applications in your area please go to
www.arun.gov.uk/planning

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Joanne Lewis <Joanne.Lewis@arun.gov.uk>

Sent: 31 March 2021 14:39

To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: RE: BN/30/21/DOC 2 Bungalows-Canal Mews-Barnham Condition 8 (EV Charging)

Dear Maria

Thank you for the extra information submitted in reference to the discharge of condition 8 (EV Charging). I have reviewed the information supplied and unfortunately this type of charging unit is not sufficient to meet the requirements of the condition.

The socket suggested is only suitable for "occasional Mode 2 EV charging" and would only supply a trickle charge, meaning that it would take all day to charge an EV battery and therefore isn't suitable as a charger for regular use by the owner of an electric vehicle.

In order to discharge the condition I would be looking for a Mode 3, 7kw fast charger as a minimum.

Joanne

Please note that I work part time, usually between 09.30 and 14.30 Tuesday – Friday.

Joanne Lewis

Senior Environmental Health Officer,
Environmental Health

T: 01903 737666

E: joanne.lewis@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)



Business Support during Coronavirus click [here](#)

From: Maria Tomalova <Maria.Tomalova@arun.gov.uk>

Sent: 30 March 2021 10:55

To: Joanne Lewis <Joanne.Lewis@arun.gov.uk>

Subject: FW: BN/30/21/DOC 2 Bungalows-Canal Mews-Barnham Condition 8 (EV Charging)

Hi Joanne,

I hope you are well.

Please see attached the required information.

Kind regards

Maria

Maria Tomalova

Senior Planning Officer
Directorate of Place

T: 01903 737510

E: maria.tomalova@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



From: Nicholas Lack <[REDACTED]>

Sent: 30 March 2021 10:43

To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>

Subject: BN/30/21/DOC 2 Bungalows-Canal Mews-Barnham Condition 8 (EV Charging)

Dear Ms Tomalova

As planning agent, I wish to submit on behalf of the applicant further information to address the consultation response of 26-03-21 from the Environmental Officer addressing a query in relation to the EV charging units under the discharge of condition 8.

Please find attached details of the EV charging unit that the applicant will be installing on each dwelling:
the **Rolec Wallpod-EV Ready** unit.

Kind regards
Nicholas Lack (Planning Agent)
Studio Lack Ltd