



Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF
Planning General Enquiries
Tel: (01903) 737756 Fax: (01903) 730442
Dx: 57406 Littlehampton
Minicom: 01903 732765
e-mail: planning@arun.gov.uk
website: www.arun.gov.uk/planning

Pegasus Goup
Whitworth Road
Cirencester
GL7 1RT

Your Ref: BN/32/17/DOC

Please ask for:

Michael Eastham

31 July 2018

Dear Miss Humphries

Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015
Application for approval of matters reserved by condition imposed under BN/16/12/
(APP/C3810/A/13/2193942) relating to conditions 5-surface water drainage, 6-maintenance of SUDs,
7-foul drainage system, 8-schedule of materials & finishes, 11-scheme for protection of retained
trees, 13-plan indicating boundary treatments, 17-ecological enhancement measures, 18-mitigation
& translocation plan for reptiles, 19-Ecological Clerk of Works for final bat checks & soft tree felling,
20-mitigation for noise sensitive facades & amenity areas, 21-pedestrian & cycle paths, 23-layout &
specifications of & construction programme for roads, including access, footpaths, foul & surface
water drainage & means of disposal, 25-pedestrian visibility splays & 26-Travel Plan.
Land at former Pollards Nursery Lake Lane, Bognor Regis,

Notification regarding the above application:

Condition Number 6

The development shall not commence until full details of the maintenance of the proposed SUDS system is set out in a site-specific maintenance manual and has been submitted to, and approved in writing, by the local planning authority. The manual shall include details of financial management and arrangements for the replacement of major components at the end of the manufacturer's recommended design life.

Decision:

Arun District Council have decided to **REFUSE** details reserved by condition for the following reasons:

The information submitted regarding Condition 7 imposed on planning permission BN/16/12: relating to the full details of the maintenance of the proposed SuDS system is set out in a site specific maintenance manual is refused and the condition is not discharged as insufficient information has been submitted to prove there would be no surface water flooding on Lake Lane.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning