

Lidsey Drainage Impact Assessment

Land Adj The Hollies, Barnham Road, Barnham PO22 0ES

- 1.1.1 Due to the location of the site, the foul water sewer discharges into the Lidsey Wastewater Treatment Works (WwTW), which is subject to stricter sewage capacity requirements. It is to be noted that only foul water from the development will discharge into the public foul sewer, ensuring that only domestic wastewater is directed to Lidsey WwTW in accordance with Southern Water's requirements and best practice for sustainable drainage design.
- 1.1.2 A CCTV drainage survey was carried out on the existing drainage network which recorded a blockage downstream of the proposed connection point. Remedial works have been carried out on the foul system and it is now clear of blockages and flowing freely.