



ARUN DISTRICT COUNCIL

- 8 JAN 2014

RECEIVED

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Developer Services
Southern Water
Southern House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref

BN/35/13/

Our Ref

PLAN-004946

Date

03/01/2014

Dear Sir

Proposal: Rear single storey extension.

Site: Clytha, Yapton Road, Barnham, PO22 0BA.

BN/35/13/

Thank you for your letter of 10/12/2013.

Please find attached a plan of the sewer records showing the approximate position of a public foul sewer crossing the site. The exact position of the public sewers must be determined on site by the applicant before the layout of the proposed development is finalised. Please note:

-No development or new tree planting should be located within 3 metres either side of the centreline of the public sewer and all existing infrastructure should be protected during the course of construction works.

-No new soakaways should be located within 5 metres of a public sewer.

Furthermore due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site. The applicant is advised to discuss the matter further with Southern Water, Southern House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk.

Southern Water requires a formal application for any new connection to the public foul sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:

"A formal application for connection to the public sewerage system is required in order to service this development. Please contact Southern Water, Southern House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk".

Our initial investigations indicate that there are no public surface water sewers in the area to serve this development. Alternative means of draining surface water from this development are required. This should not involve disposal to a public foul sewer.

Yours faithfully


Developer Services

SOUTHERN WATER



The positions of pages listed in this plate are believed to be correct, but Southern Water Services Ltd accepts no responsibility in the event of inaccuracy. The actual positions should be checked on site.

Based upon Copyright Clearance Center's Digital Library with the permission of the copyright owner, B. B. & C. Church Copyright Clearance Center, Inc. 9781, 2nd Fl.

C.S. REF. SL9503NE

Scale: 1:1250

Screen Print

WARRANTY: These papers are constructed of Recycled Address Envelopes.

WARNING: Inhalation of SX material may include flammable Acheson Company



Printed By: hamish

Date: 3-1-2014

Southern Water MapGuide Browser

Requested By: