

[REDACTED]

From: Nicholas Lack [REDACTED]
Sent: 12 June 2019 11:06
To: Simon Davis <Simon.Davis@arun.gov.uk>
Cc: David West [REDACTED]
Subject: BN/35/19/DOC Lake Lane External Lighting condition.

Dear Simon

I have spoken with the applicant who agrees to the time limits on the external bollard lighting proposed.

Kind regards
Nicholas Lack (Planning Agent)
Studio Lack Ltd

From: Simon Davis <Simon.Davis@arun.gov.uk>
Sent: 12 June 2019 10:27
[REDACTED]
Subject: FW: BN/35/19/DOC Lake Lane External Lighting condition.

Hi Nicholas,

Would the below be acceptable?

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |

Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Joanne Lewis <Joanne.Lewis@arun.gov.uk>

Sent: 12 June 2019 10:00

To: Simon Davis <Simon.Davis@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: RE: BN/35/19/DOC Lake Lane External Lighting condition.

Simon,

If the applicant confirms that the lights will be switched off between 23.00 hours and 05.30 hours (when necessary in the darker months) in line with West Sussex Street Lighting, this will be acceptable to discharge the condition.

Joanne

Please note my normal working days are Wednesday, Thursday and Friday.

Joanne Lewis | Senior Environmental Health Officer, [Arun District Council](http://www.arun.gov.uk) | Location: Arun Civic Centre, Maltravers Road,
Littlehampton, BN17 5LF

Internal: 37666 | External: +44 (0) 1903 737666 | E-mail: joanne.lewis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.