

To register to receive notification of planning applications in your area please go to
www.arun.gov.uk/planning

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>
Sent: 02 March 2021 10:38
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Maria Tomalova <Maria.Tomalova@arun.gov.uk>
Subject: RE: Notification of an appeal BN/46/20/PL

Hi Maria,

I am not sure if you have written up recommended conditions for the Inspector in this appeal yet, but I would like to reiterate the request for condition PCENG2 to be applied. It is acknowledged that the applicant has supplied a General Drainage Specifications/Layout, however it appears that no infiltration testing or groundwater monitoring has been undertaken to inform the detailed design. No detailed design, calculations or construction details have been supplied as yet.

Kind Regards

Sarah Burrow
Engineering Assistant, Engineering Services

T: 01903 737815
E: sarah.burrow@arun.gov.uk



Whilst national restrictions are in place I will be working flexibly between the hours of 8am and 8pm. I appreciate your patience if I am slower than usual to respond. Equally I understand that you may be facing similar challenges and varying work patterns and will not be expecting immediate responses to my e-mails.

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)

From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 18 January 2021 09:34

To: Land Drainage [REDACTED]

Subject: Notification of an appeal BN/46/20/PL