



Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Your Ref
BN/50/18/PL
Our Ref
PLAN-025490
Date
06/12/2018

Dear Sirs,

Proposal: Erection of 1 No. replacement dwelling & conversion of existing out building (approved dwelling) into double garage.
Site: The Fallows, Highground Lane, BARNHAM PO22 0BT.
BN/50/18/PL

Thank you for your letter of 06/11/2018.

Southern Water would not support the proposals for septic tank or private treatment plant in the presence of public foul sewerage network in the close vicinity of the development site. The foul sewerage shall be disposed in accordance with Part H1 of Building Regulations hierarchy.

It may be possible for the foul flows from the proposed development to be connected to a nearby public sewer, and the applicant shall investigate this option. The applicant should assure himself that he has adequate rights to utilise the intervening private drainage systems. Otherwise the connection to the public sewerage system could be requisitioned under the terms of the Water Industry Act. Southern Water requires a formal application for a connection to the public sewer. The applicant is advised to contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link <https://beta.southernwater.co.uk/infrastructurecharges>.

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

Due to surface water inundation issues in the Lidsey Catchment "The applicant is advised to adopt, where appropriate, the measures in the table "Practical measures to reduce the potential impacts of development".

Developer should look to protect the public sewerage system from inundation and infiltration, which contribute to flooding in unfavourable conditions.

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk

Yours sincerely,



Luis Silva
Developer Services

