

From: Laura Gibbons
Sent: 26 March 2019 14:29
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: BN/50/18/PL The Fallows

Hi Simon,

It is unclear if the crates proposed would be suitable for such shallow cover depths. Furthermore, as detailed on the soakaway detail plans 100mm sand is required above the crates, this leaves only 100mm topsoil which wouldn't be sufficient to support grass growth. Shallower crates are available and should be looked at.

Furthermore, a location plan showing the soakaways and upstream pipe work including catchpits needs to be provided. This plan needs to include invert and cover levels.

Feel free to point the applicant in the direction of our checklist <https://www.arun.gov.uk/drainagechecklist> for further information as to our requirements.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

[Laura Gibbons](#) | Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



From: Simon Davis
Sent: 25 March 2019 13:24
To: Planning.Responses; Laura Gibbons
Subject: FW: BN/50/18/PL The Fallows

Planning.Responses – please see Action Sheet

Laura – can you advise re conditions.