

From: Simon Davis
Sent: 28 March 2019 09:13
To: Planning.Responses
Subject: FW: BN/50/18/PL The Fallows

Further Drainage Comments.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 28 March 2019 08:52
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: BN/50/18/PL The Fallows

Simon,

I have reviewed the minimum cover depths recommended by the manufacturer. All of the potential crate types require a minimum cover depth of 300mm in non-trafficked areas. Furthermore, the crates must have 100mm coarse sand over the top. Therefore, the proposals are unacceptable, and I would once again recommend the applicant looks at using a shallower crate or lowering the proposed invert. Our requirements are only that infiltrating structures are located above maximum recorded groundwater levels.

I note that calculations for two soakaways are provided, yet only one is shown on the layout plan. Please ensure that layout plans meet calculation requirements.

I did not explicitly state previously our requirements for the layout plan, as I presumed the applicant would look at our checklist. The layout plan needs to be updated to ensure that it includes:

- All surface water drainage pipes labelled with; diameters, pipe materials, falls and invert levels.
- All infiltrating structures (including permeable paving) labelled with; dimensions, invert and cover levels.
- All manholes labelled with; cover levels, invert levels, cover types detailed.
- All silt traps clearly labelled with sump depths.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 27 March 2019 11:03
To: Laura Gibbons; Planning.Responses
Subject: FW: BN/50/18/PL The Fallows

Planning.Responses – please see Action Sheet

Laura – further plans/details for you to consider (ignore the attached email as you have already seen this).

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: [REDACTED]
Sent: 27 March 2019 10:45
To: Simon Davis <Simon.Davis@arun.gov.uk>
Cc: [REDACTED]
Subject: Re: BN/50/18/PL The Fallows

Simon

drainage layout plan attached showing position of soakaway, drain runs and catch pits

also attached is updated soakaway drawings showing omitted the course sand layer over the crates. 200mm of topsoil will now be able to be placed over the soakaway crates to readily allow grass growth. As noted on the drawings the Aquacell crates (Core or Plus units should be installed) shall not be located under vehicular areas.

Kind regards

Steve Jupp

Stephen Jupp MRTPI
Chartered Town Planner
Sally Field Lodge
Rotten Row
Sidlesham
West Sussex
PO20 7QB

On 26 Mar 2019, at 17:41, Simon Davis <Simon.Davis@arun.gov.uk> wrote:

Hi Steve,

Drainage advice received today in response to your email is that:

"It is unclear if the crates proposed would be suitable for such shallow cover depths. Furthermore, as detailed on the soakaway detail plans 100mm sand is required above the crates, this leaves only 100mm topsoil which wouldn't be sufficient to support grass growth. Shallower crates are available and should be looked at.

Furthermore, a location plan showing the soakaways and upstream pipe work including catchpits needs to be provided. This plan needs to include invert and cover levels.

Feel free to point the applicant in the direction of our checklist <https://www.arun.gov.uk/drainagechecklist> for further information as to our requirements."

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
