

[REDACTED]

From: Simon Davis
Sent: 01 April 2019 10:37
To: 'stephen jupp' [REDACTED]
Cc: Danny Keet [REDACTED]
Subject: RE: BN/50/18/PL The Fallows

Dear Steve,

I have had advice from Laura re rainwater harvesting. However, I understand from Danny that a revised scheme is coming in though so am providing this advice for info only:

“We do not take into account rainwater harvesting systems because the largest rainfall volumes are seen in the winter when reuse demands are at their lowest, and people go on holiday etc. i.e. we have no control over them.”

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: stephen jupp [REDACTED]
Sent: 28 March 2019 10:39
To: Simon Davis [REDACTED]
Cc: Danny Keet [REDACTED]
Subject: Re: BN/50/18/PL The Fallows

Simon

the requirement for invert depths is impossible until a levels survey is done.
It does seem a very onerous requirement for a single plot.
If we decide to go for rainwater harvesting what sort of details are going to be required?

Kind regards

Steve Jupp

Stephen Jupp MRTPI
Chartered Town Planner

Sally Field Lodge
Rotten Row
Sidlesham
West Sussex
PO20 7QB

