

From: Laura Gibbons
Sent: 01 April 2019 09:46
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: BN/50/18/PL The Fallows

Hi Simon,

We do not take into account rainwater harvesting systems. This is because largest rainfall volumes are seen in the winter when reuse demands are at their lowest, and people go on holiday etc. i.e. we have no control over them.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 28 March 2019 12:48
To: Laura Gibbons
Subject: FW: BN/50/18/PL The Fallows

Hi Laura,

Any advice on the rainwater harvesting matter? I am minded to say it's the same for everyone (within the Lidsey area) re his other point.

From: stephen jupp [REDACTED]
Sent: 28 March 2019 10:39
To: Simon Davis <Simon.Davis@arun.gov.uk>
Cc: Danny Keet [REDACTED]
Subject: Re: BN/50/18/PL The Fallows

Simon

the requirement for invert depths is impossible until a levels survey is done.
It does seem a very onerous requirement for a single plot.
If we decide to go for rainwater harvesting what sort of details are going to be required?

Kind regards

Steve Jupp

Stephen Jupp MRTPI
Chartered Town Planner
Sally Field Lodge
Rotten Row
Sidlesham
West Sussex
PO20 7QB

[REDACTED]