SPECIFICATION NOTES

1. ALL DRAINAGE SHALL BE CONSTRUCTED AND COMMISSIONED IN ACCORDANCE WITH BS EN 295 & BS EN752, BUILDING REGULATIONS DOC. H AND ANY PARTICULAR REQUIREMENTS OF THE BUILDING CONTROL OFFICER.

2. DRAIN BEDDING IS TO BE PROVIDED AS D200.0, D200.1 and D200.2 AS SHOWN ON THE DRAINAGE DETAILS SHEETS.

3. 'EFFECTIVE COVER' IS THE MINIMUM DEPTH OF COVER OVER THE PIPE CROWN AT ANY TIME DURING THE CONSTRUCTION PROCESS.

4. ALL CONCRETE PIPEWORK, MANHOLES AND FITTINGS SHALL BE TO BS 5911 (ALL RELEVANT PARTS), ALL CONCRETE PIPEWORK TO BE TO HIGH STRENGTH

5. WHERE CONNECTIONS ARE TO BE MADE TO EXISTING MANHOLES/SEWERS, INVERT LEVELS, PIPE SIZES & ORIENTATION SHALL BE CHECKED PRIOR TO THE COMMENCEMENT OF THE WORKS AND ANY VARIANCE REPORTED TO THE ENGINEER IMMEDIATELY.

6. WHERE PIPELINES CROSS, EACH 3S TO BE SURROUNDED WITH GRADE ST4 MASS CONCRETE FOR A DISTANCE NOT LESS THAN 1m CENTRED ON THE CROSSING POINT. LENGTH OF SURROUND TO BE EXTENDED AS NECESSARY TO WITHIN 150mm OF THE NEXT NEAREST FLEXIBLE JOINTS.

7. THE CONTRACTOR IS TO ENSURE THAT PROTECTIVE MEASURES ARE TAKEN TO ENSURE THAT DRAINAGE PIPEWORK AND FITTINGS ARE NOT DAMAGED BY SITE TRAFFIC PRIOR TO OVERSITE FILLING OPERATIONS BEING COMPLETED AROUND BUILDINGS.

8. ALL PRIVATE DRAINAGE PIPEWORK SHALL BE PVCu. ALL ADOPTED DRAINAGE TO BE VC. ALL UNDERBUILDING DRAINS TO BE LAID AT A GRADIENT OF 1:40

9. WHERE DRAINS PASS THROUGH FOUNDATIONS OR CONNECT TO MANHOLES, FLEXIBLE PIPE JOINTS ARE TO PROVIDED WITHIN 150mm OF THE FACE OF THE STRUCTURE AND WITHIN A FURTHER 600mm TO FORM A ROCKER PIPE.

10. WHERE PIPES PASS THROUGH SCREEN WALLS, FOOTINGS OR RETAINING WALLS, LINTELS ARE TO BE PROVIDED.

11. WHERE PIPELINES PASS WITHIN 1m OF BUTLDINGS OR WALLS THE FOUNDATIONS ARE TO BE TAKEN DOWN BELOW THE BOTTOM OF THE TRENCH

12. 450mm DIA. INSPECTION CHAMBERS (TFC/SC) MAY BE USED:
- WITH 350mm REDUCED OPENING WHERE THE DEPTH FROM COVER TO INVERT EXCEEDS 1000mm.

300mm DIA. POLYPROPYLENE ACCESS CHAMBERS (FAC/SAC) MAY BE USED
- WHERE THE DEPTH FROM COVER TO INVERT DOES NOT EXCEED 600mm AND WHERE THE PIPE SIZE DOES NOT EXCEED 100mm DIA.

13. STEEL COVERS WITHIN PROPERTY BOUNDARIES SHALL BE:
(UNLESS NOTED ON DRAWING OR MANHOLE SCHEDULE)
-ON PRIVATE DRIVEWAYS: FACTA GRADE B (BS EN ISO 1461: 1999)
-ON PRIVATE PATHWAYS, VERGES OR ON GARDENS: FACTA GRADE A (BS EN ISO 1461: 1999)

DUCTILE IRON COVERS OUTSIDE PROPERTY BOUNDARIES SHALL BE:
(UNLESS NOTED ON DRAWING OR MANHOLE SCHEDULE)
-ON ACCESS ROADS AND CAR PARKS: GRADE D400 (BS EN 124:1994)
-ON SHARED PATHWAYS, VERGES: GRADE A15 (BS EN 124:1994)

14. COVER LEVELS SHOWN 'CL' AND INVERT LEVELS SHOWN 'IL' ARE IN METRES ABOVE ORDNANCE DATUM.

15. ALL DRAINS TO BE 100mm DIAMETER UNLESS NOTED OTHERWISE

16. ALL DRAINS MARKED 'FWS' OR 'SWS' ARE PROPOSED ADOPTED SEWERS AND ARE TO BE CONSTRUCTED IN ACCORDANCE WITH 'SEWERS FOR ADOPTION, 7TH EDITION'

17. DRAINAGE CONNECTIONS NOT DIRECT TO A CHAMBER TO BE VIA AN OBLIQUE 45° JUNCTION

18. ALL CONNECTIONS INTO MANHOLES TO BE MADE SOFFIT TO SOFFIT UNLESS STATED OTHERWISE.

KEY

- Existing Ditch/watercourse
- Private surface water drain
- Private foul drain
- Adoptable foul sewer
- Adoptable highway drain/ SW sewer
- FIC — Foul Plastic Inspection Chamber - D202.6
- SIC — Surface Water Plastic Inspection Chamber - D202.6
- SCP — 50/4 SEL Control chamber SUDS02005 with orifice plate. Refer to plan for size.
- SAC — 300mm diameter Surface Water Access Chamber - D202.18
- FAC — 300mm diameter Foul Water Access Chamber - D202.18
- YG — Yard gully - 300# x 600mm deep
- RG — Adoptable road gully
- RG — Private road gully
- F9 — Adoptable Foul water Sewer Manhole
- S13 — Adoptable Surface water manhole
- SVP — Foul drain point D307.0
- RP — Drain rodding point
- RWP — SW Drain point for RWP D203.5
- Drainage channel
- 300mm wide x 450mm deep gravel filled french drain
- Area of voided stone under permeable paving - refer to external works layouts for details
- DT — Distribution tank (inlet) from roof drainage in permeable paving sub-base. See detail on drg 2101
- DT — Distribution tank (Outfall) in permeable paving sub-base. See detail on drg 2101
- Proposed external levels

ABBREVIATIONS

D307.0	DETAIL NUMBER - SEE DRAINAGE DETAIL SHEET
FD	FOUL DRAIN
SWD	SURFACE WATER DRAIN
FWS	ADOPTABLE FOUL WATER SEWER
SWS	ADOPTABLE SURFACE WATER SEWER
MH	MANHOLE
IC	INSPECTION CHAMBER
SA	SOAKAWAY
FIC	450mm DIA. FOUL INSPECTION CHAMBER - D202.6
SIC	450mm DIA. SURFACE WATER INSPECTION CHAMBER - D202.6
FAC	300mm DIA. FOUL ACCESS CHAMBER - D202.18
SAC	300mm DIA. SURFACE WATER ACCESS CHAMBER - D202.18
CI	CAST IRON
VC	VITRIFIED CLAY
CONC	CONCRETE
PVC-U	POLYVINYL CHLORIDE - UNPLASTICISED
G	SMALL GULLY - D209.0
YG	YARD GULLY - D209.2
RG	ROAD GULLY - D209.1
CPG	CAR PARK GULLY - D208.2
DP	BELOW GROUND DRAIN POINT
SVP	SOIL VENT PIPE DROP
RP	EXTERNAL RODDING POINT - D213.1
DT	SURFACE WATER DISTRIBUTION TANK
FFL	FINISHED FLOOR LEVEL
SSL	STRUCTURAL SLAB LEVEL
GL	GROUND LEVEL
CL	COVER LEVEL
IL	INVERT LEVEL
SL	SLIMP LEVEL
BL	BASE LEVEL
HL	HIGH LEVEL
BD	BACKDROP
CBS	CONCRETE BED & SURROUND
CLASS S	GRANULAR BED & SURROUND
CLASS B	GRANULAR BED

GENERAL NOTES:

1. All dimensions to be checked on site. All details and dimensions relating to sub-contractors or suppliers work must be checked and agreed between the sub-contractor or supplier and the main contractor.

2. This drawing is to be read in conjunction with all relevant architects, services and engineers drawings and specifications.

3. The location, size, depth and identification of existing services that may be shown or referred to on this drawing have been assessed from non intrusive observations , record drawings or the like. The contractor shall safely carry out intrusive investigations, trial holes or soundings prior to commencing work to satisfy himself that it is safe to proceed and that the assessments are accurate. Any discrepancies shall be notified to gsp prior to works commencing.

4. Tender or billing drawings shall not be used for construction or the ordering of materials.

5. Do not scale, All dimensions and levels to be site confirmed.

6. Copyright : This drawing must not be copied, amended nor reproduced without the prior written agreement of gsp.

DESIGN NOTES

1. STORAGE DESIGN BASED ON 1 IN 100 YR STORM + 40%.

2. DRAIN POINTS AND LOCATIONS TO BE CONFIRMED BY ARCHITECT.

3. CONTRACTOR TO ESTABLISH LOCATIONS OF ALL EXISTING SERVICES PRIOR TO COMMENCING.

4. EXISTING TREES TO BE PROTECTED WHERE EXCAVATIONS RUN CLOSE.

5. DESIGN SUBJECT TO APPROVAL FROM SOUTHERN WATER FOR CONNECTIONS TO SEWERS AND ADOPTION OF SEWERS.

6. DESIGN SUBJECT TO APPROVAL FROM WSCC FOR ADOPTABLE ROADS AND DRAINAGE.

7. DESIGN SUBJECT TO APPROVAL FROM WSCC.

8. DISCHARGE TO EXISTING WATER COURSE SUBJECT TO ORDINARY WATERCOURSE CONSENT FROM WSCC.

NOTE
All ditches on the site for which Redrow has riparian responsibility to be cleared/desilted to the satisfaction of the ADC drainage engineer

REV	DATE	DESCRIPTION	BY	CHK	APP
C4	24.09.20	Revised to WSCC comments	SDL	MR	GO
C3	17.09.20	Revised to WSCC comments	SDL	MR	GO
C2	28.08.20	Foul & surface water revisions	SDL	MR	GO
C1	25.08.20	CONSTRUCTION ISSUE	SDL	MR	GO
T3	06.08.20	Tank and catchpit revised. Foul sewer level revised	SDL	MR	GO
T2	30.07.20	Revised to latest layout	SDL	MR	GO
T1	10.07.20	TENDER ISSUE	SDL	MR	GO
P5	18.06.20	Updated to latest layout	SDL	MR	GO
P4	21.02.20	Updated to Client comments	GS	SDL	GO
P3	21.01.20	Updated to client comments	CM	MR	
P2	23.12.19	Updated to latest scheme	MR	MR	
P1	06.11.19	INITIAL ISSUE	SL	MR	

Gyoury Self
CONSULTING ENGINEERS
16/17 BOUNDARY ROAD, HOVE,
EAST SUSSEX BN3 4EF
TELEPHONE: 01273 414413
E-MAIL: mail@gsphove.co.uk
Website: www.gyouryself.com
Also at Fareham and St Albans

CLIENT: REDROW HOMES

ARCHITECT: RHP

JOB TITLE: ANGEL & HYDE NURSERIES
YAPTON ROAD
BARNHAM

DRAWING TITLE: SITE DRAINAGE
SHEET 1 OF 2

JOB No.	SCALE @ A1	DATE
H19812	1/200	NOVEMBER 2019

DRAWN	ENGINEER	CHECKED	APP
MR	GTA		

STATUS: D1 — DRAWING SUITABILITY: SUITABLE FOR CONSTRUCTION

REVISION: C4 — RDN STATUS: STAGE 5 – CONSTRUCTION

DRAWING No.: 19812-GS-Z1-XX-DR-C-2060