

Plots	FFL		Variance	
	Design	As Built		
Apartment Block 2	9.800	9.870	0.070	0.71%
34	9.800	9.860	0.060	0.61%
33	9.800	9.850	0.050	0.51%
35	9.800	9.840	0.040	0.41%
36	9.800	9.840	0.040	0.41%
37	9.800	9.840	0.040	0.41%
66	9.800	9.880	0.080	0.82%
67	9.800	9.870	0.070	0.71%
68	9.800	9.870	0.070	0.71%
69	9.800	9.870	0.070	0.71%
70	9.800	9.880	0.080	0.82%
71	9.800	9.870	0.070	0.71%
72	9.800	9.870	0.070	0.71%
73	9.800	9.880	0.080	0.82%
74	9.800	9.860	0.060	0.61%
75	9.800	9.850	0.050	0.51%
76	9.800	9.880	0.080	0.82%
Averages			0.064	0.65%

Notes:

all FFLS within allowable construction tolerances with and average level variance of 6.4mm between design and as built