




From: [REDACTED]
Sent: 29 January 2019 19:13
To: Andrew Wood
Cc: Ben Kirk
Subject: Re: BN/54/18/DOC - Land North of The Flint Barn - Drainage Conditions

Andrew

We would like to formally withdraw this application at this time

Could you please confirm receipt of this request

Many thanks

Kind regards

Ben kirk

On 23 Jan 2019, at 11:47, Andrew Wood <Andrew.Wood@arun.gov.uk> wrote:

Mr. Kirk,

BN/54/18/DOC - Land North of The Flint Barn - Drainage Conditions

I believe I will be able to alter the description of the application subject to you confirming the change of description you would like by return of email.

I have been reminded that further details are required from you . It may be worth liaising directly with Laura Gibbons. See contact details and message below Thank you,

Please provide additional details by 14th February 2019 or I will determine the application on the basis of inadequate information.

Thank you,

Andrew Wood

Andrew Wood MRTPI | Senior Planning Officer, Planning Department, Arun District Council |
Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37768 | External: +44 (0) 1903 737768 | E-mail: andrew.wood@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons

Sent: 09 January 2019 15:45

To: Andrew Wood

Subject: RE: BN/54/18/DOC - Land North of The Flint Barn - Drainage Condition

Hi Andrew,

Engineers Comments Regarding Conditions 3,4 and 5

The submitted information is inadequate, and therefore I do not recommend the discharge of this condition.

As stated on the previous application (BN/29/18/DOC) the surface water drainage design must be able to accommodate the 1 in 100 year plus 40% climate change event. Land drainage consent has not been obtained and details are lacking.

I have attached our checklist to aid the applicant on the level of detail required to successfully discharge these conditions, and I advise that they contact us.

Kind Regards,

Laura Gibbons, MEng, GMICE

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltrovers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<Surface Water Drainage Submissions Checklist 191218.pdf>