



from
**Southern
Water**

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref
BN/54/21/DOC

Our ref
PLAN-039181

Date
15/06/2021

Contact

Dear Sir/Madam,

Proposal: Approval of details reserved by condition imposed under ref BN/50/20/PL relating to Condition Nos 5 - mitigation method statement, 6 - archaeology, 7 - piling risk assessment & method statement, 8 - Construction & Environmental Management Plan, 9 - foul drainage, 10 - surface water drainage, 11 - maintenance & management of surface water drainage, 13 - pre-commencement site meeting, 15 - odour assessment or evidence that livery has ceased, 16 - soil resource plan, 17 - landscaping, 18 - screen walls & fences, 19 - elevation details of 2 proposed communal bin stores and 20 - colour schedule of materials & finishes.

Site: BN/54/21/DOC: - Land Rear of 1 Northfields Cottages, Fontwell Avenue, Eastergate, PO20 3RX.

Further to our previous correspondence dated 27/05/2021 regarding the above planning consultation and further information provided by the developer regarding sewer diversion.

Southern Water cannot recommend discharge of condition 09 and 10 relating to foul and surface water drainage until such time any sewer diversion proposals currently being dealt under our reference DSA000002020 has been agreed and approved by Southern Water before implementing on site.

No discharge of foul sewerage from the site shall be discharged into the public system until offsite drainage works to provide sufficient capacity within foul network to cope with additional sewerage flows are complete. Southern Water is currently in process of designing and planning delivery of offsite sewerage network reinforcements. As previously advised Southern Water seeks to limit the timescales to a maximum of 24 months from a firm commitment of the development.

No soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of public or adoptable gravity sewers, rising mains or water mains.

The applicant proposes to retain the SuDs within private ownership and maintenance. Hence, Southern Water would have no comments for condition 11 relating to Suds Maintenance.

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366870

Southern Water have no comments to make with regards to other conditions.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX [REDACTED].

Website: southernwater.co.uk or by email at: [REDACTED]

Yours faithfully,

Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU9406SE

Scale: 1:1250

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement



Printed By: rudraps

Date: 20-5-2021

Southern Water MapGuide Browser

Requested By:

