

[REDACTED]

From: Mark Warwick <Mark.Warwick@arun.gov.uk>

Sent: 13 May 2021 15:58

To: Lauren Wiltshire [REDACTED] Stuart Knight
[REDACTED]

Cc: Simon Davis <Simon.Davis@arun.gov.uk>

Subject: RE: BN/50/20/PL (Condition 13) - Pre-commencement site meeting (Tree Protection Measures)

Dear Lauren and Stuart

I apologise for missing the 11am meeting; my previous meeting had overrun and then I was caught in slow traffic on my way to your site. I elected to keep driving rather than pull-over and make a call to you and so arrived just before 11:15am. Clearly everyone had left by then.

I can report that the vast majority of Tree Protection Fencing is correctly located and installed 'fit for purpose', although there are a number of significant anomalies which will need to be resolved prior to commencement and to ensure adherence with the approved Arboricultural Impact Assessment and Method Statement. Described as follows:

- Fence line is open at NW corner of site.
- Fence line is open at existing 5-bar gated access from Fontwell Avenue.
- All-weather notices attached to HERAS panels are scarce and their message lacks authority, appearing more to be an advertisement for the tree work contractor who provided them. The following important wording is missing – '*Construction Exclusion Zone – NO ACCESS*'.
- There are no day-glo ribbons attached to the top of the barrier, to ensure the fencing is clearly visible during the works.

Please can you confirm in writing and by providing photographic evidence, as soon as those refinements have been made.

Kind regards,

Mark Warwick
Tree Officer, Greenspace Team



T: 01903 737974

E: mark.warwick@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)