

Hampshire Homes Group
Chatmohr Estate, Unit 8
Crawley Hill
West Wellow
Romsey
SO51 6AP

Date: 1st July 2021

Please ask for: Mr S Davis
Tel: 01903 737874

Your Ref:

Our Ref: BN/54/21/DOC

Dear Miss Wiltshire,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under ref BN/50/20/PL relating to Condition Nos 5 - mitigation method statement, 6 - archaeology, 7 - piling risk assessment & method statement, 8 - Construction & Environmental Management Plan, 9 - foul drainage, 10 - surface water drainage, 11 - maintenance & management of surface water drainage, 13 - pre-commencement site meeting, 15 - odour assessment or evidence that livery has ceased, 16 - soil resource plan, 17 - landscaping, 18 - screen walls & fences, 19 - elevation details of 2 proposed communal bin stores and 20 - colour schedule of materials & finishes.

Land Rear Of 1 Northfields Cottages Fontwell Avenue Eastergate PO20 3RX

Notification regarding the above application:

Condition Number 10

Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

Decision:

Arun District Council have decided to **REFUSE details reserved by condition for the following reasons:**

Council Drainage Engineers have stated that they cannot currently properly review or agree the proposals for the various reasons set out in their consultation response of 11/06/21 (available on our website). It is acknowledged that this information was not forwarded to you but it was available on the public website. In addition, it was clear that the specific requirements of the condition had not been met (such as winter infiltration and groundwater testing). As such, the condition cannot be discharged and you will need to make a revised submission.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning