

From: Amanda Scholes on behalf of Planning.Responses
Sent: 17 August 2020 10:55
To: Planning Scanning
Subject: FW: Hydrant condition - BN/57/19/RES Land East of Fontwell Avenue Fontwell Avenue Fontwell BN18 OSB
Attachments: Hydrant Condition - BN.57.19.RES Land East of Fontwell Avenue Fontwell Avenue Fontwell BN18 OSB.docx

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)  Save the environment - think before you print.

From: Raymond Cole <Raymond.Cole@arun.gov.uk>
Sent: 17 August 2020 10:42
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: Hydrant condition - BN/57/19/RES Land East of Fontwell Avenue Fontwell Avenue Fontwell BN18 OSB

Thanks Zoe

Please could you upload the correspondence and the attachment to the application folder BN/57/19/RES as a consultation response from West Sussex Fire and Rescue?

Thank you

Raymond Cole
Principal Planning Officer
Directorate of Place

T: 01903 737598
E: raymond.cole@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Zoe Toppin <Zoe.Toppin@arun.gov.uk> **On Behalf Of** Planning.Responses
Sent: 12 August 2020 13:30

To: Raymond Cole <Raymond.Cole@arun.gov.uk>

Subject: FW: Hydrant condition - BN/57/19/RES Land East of Fontwell Avenue Fontwell Avenue Fontwell BN18 0SB

Zoe Toppin


Planning Apprentice, Planning

T: 01903 737500 ext 37889

E: zoe.toppin@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)



From: Ian Stocks [REDACTED] On Behalf Of FRS Water and Access

Sent: 12 August 2020 13:14

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Hydrant condition - BN/57/19/RES Land East of Fontwell Avenue Fontwell Avenue Fontwell BN18 0SB

FAO: Raymond Cole

Dear Raymond,

Please find attached a planning condition for application no. BN/57/19/RES for the requirement of an additional fire hydrant. Currently the nearest Hydrant to these proposed properties is 290 metres away. The supply of water for firefighting for a commercial premises should be within 90 metres.


Regards

Ian Stocks

Water & Access manager

Water and Access Office
West Sussex Fire and Rescue Service [West Sussex County Council](#)
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB
[REDACTED]

Living Our Values Every Day



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

.....

WEST SUSSEX COUNTY COUNCIL
WEST SUSSEX FIRE AND RESCUE SERVICE

HYDRANT CONDITION CONSULTATION WITH PLANNING AUTHORITY

Date: 12/08/2020

To: Raymond Cole

From: Ian Stocks

Planning Ref: BN/57/19/RES

Address: Land East of Fontwell Avenue, Fontwell Avenue, Fontwell,
West Sussex, BN18 0SB

Description: Approval of reserved matters for 3785sqm of light industrial
floorspace (Class B1 (b)/(c)) following the grant of
WA/22/15/OUT.

Date of visit: N/A

RECOMMENDATION

Advice: ☒

Modification: ☐

More Information: ☐

Objection: ☐

No Objection: ☐

Refusal: ☐

Total number of hydrants required

1

This application has been dealt with in accordance with the statutory obligation placed upon Fire and Rescue Service by the following act;

***Fire and Rescue Services Act 2004
Part 5, 38: Duty to secure water supply etc.***

- 1) *A fire and rescue authority must take all reasonable measures for securing that an adequate supply of water will be available for the authority's use in the event of fire.*

This proposal has been considered by means of desktop study, using the information and plans submitted with this application, in conjunction with other available WSCC mapping and Fire and Rescue Service information. A site visit can be arranged on request.

I refer to your consultation in respect of the above planning application and would provide the following comments:

- 1) Prior to the commencement of the development details showing the proposed location of [1] one fire hydrant or stored water supply (in accordance with the West Sussex Fire and Rescue Guidance Notes) shall be submitted to and approved in writing by the Local Planning Authority in consultation with West Sussex County Council's Fire and Rescue Service. These approvals shall not be unreasonably withheld or delayed.
- 2) Prior to the first occupation of any dwelling/unit forming part of the proposed development that they will at their own expense install the fire hydrant (or in a phased programme if a large development) in the approved location to BS 750 standards or stored water supply and arrange for their connection to a water supply which is appropriate in terms of both pressure and volume for the purposes of firefighting.

The fire hydrant shall thereafter be maintained as part of the development by the water undertaker at the expense of the Fire and Rescue Service if adopted as part of the public mains supply (Fire Services Act 2004) or by the owner / occupier if the installation is retained as a private network.

As part of the Building Regulations 2004, adequate access for firefighting vehicles and equipment from the public highway must be available and may require additional works on or off site, particularly in very large developments. (BS5588 Part B 5) for further information please contact the Fire and Rescue Service

If a requirement for additional water supply is identified by the Fire and Rescue Service and is subsequently not supplied, there is an increased risk for the Service to control a potential fire. It is therefore recommended that the hydrant condition is implemented

Reason: In the interests of amenity and in accordance with policy INF SP1 and TSP1 of the Arun Local Plan 2011-2031 and in accordance with The Fire & Rescue Service Act 2004.

Ian Stocks
Water and Access Manager

Email: [REDACTED]