

Grove Design UK

Date: 24th June 2022

Your Ref:

Please ask for: Amber Willard

Our Ref: BN/57/22/DOC

Tel: 01903 737500 x37445

Dear Mr Hollands,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under ref BN/152/20/PL relating to Condition Nos 3 - surface water drainage and 4 - discharge flows to watercourses.

Land adjacent to 49 Warren Way Barnham PO22 0JX

Notification regarding the above application:

Condition Number 3

Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

Decision:

Arun District Council have decided to **REFUSE details reserved by condition for the following reasons:**

The condition cannot be discharged at this stage. The information submitted is not adequate to discharge the conditions and there has been insufficient time to address the additional information submitted.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, consisting of stylized initials 'NC' followed by a small dot.

Neil Crowther
Group Head of Planning