

From: Laura Gibbons
Sent: 05 March 2019 09:18
To: Planning.Responses
Cc: Michael Eastham
Subject: RE: Planning Consultation on BN/5/19/DOC

Engineers Comments Regarding Condition 5- surface water drainage

Plans have been submitted that show that the proposal is to connect the surface water drainage from this development into the existing site surface water drainage. However, no calculations etc. have been provided which demonstrate there is adequate capacity within the existing system to cope with these additional flows. Please can the applicant submit calculations which include the new and existing networks.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 22 February 2019 10:34
To: Land Drainage
Subject: Planning Consultation on BN/5/19/DOC

To: Engineers (Drainage)

**NOTIFICATION FROM ARUN DISTRICT COUNCIL
TOWN AND COUNTRY PLANNING ACT 1990**

APPLICATION BN/5/19/DOC
NO:

Registered: 18-FEB-19
Site Address: Land at Former Pollards Nursery

Description of Works:

Approval of details reserved by condition imposed under ref BN/49/18/PL relating to Condition Nos 3, 4, 5, 6, 10 and 11.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 8th March 2019.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Michael Eastham who can be contacted on telephone number 01903 737772.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
