

**From:** Laura Gibbons  
**Sent:** 02 September 2019 14:44  
**To:** Amber Willard <Amber.Willard@arun.gov.uk>  
**Subject:** FW: BN/60/19DOC 86 Elm Grove, Barnham

Hi Amber,

The applicant has confirmed some points regarding this application. The development is small, no new rainwater pipes are being proposed, an existing connection to a surface water sewer exists, groundwater levels and site levels make it impossible to provide an infiltration solution. I am therefore happy to recommend that condition 3 is discharged.

Kind Regards,

Laura Gibbons, MEng, GMICE  
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: [laura.gibbons@arun.gov.uk](mailto:laura.gibbons@arun.gov.uk)

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and [www.chichester.gov.uk](http://www.chichester.gov.uk)



Save the environment - think before you print.

**Sent:** 30 August 2019 10:41  
**To:** Laura Gibbons <[Laura.Gibbons@arun.gov.uk](mailto:Laura.Gibbons@arun.gov.uk)>  
**Subject:** BN/60/19DOC 86 Elm Grove, Barnham

Dear Laura,

Following our telephone conversation this morning, I confirm the rainwater will be flowing down the existing surface water downpipes.

No alterations are needed to the existing rainwater drains, as shown in drawing for 86 Elm Grove which were sent along with Southern Water's approval letter.

Many Thanks for your assistance in this matter and I look forward to receiving that the confirmation that the planning restriction has been removed.

Yours Sincerely,

John Howard

