




---

**From:** Kate Giddings  
**Sent:** 10 September 2019 12:50  
**To:** Michael Eastham <Michael.Eastham@arun.gov.uk>  
**Cc:** Planning.Responses <Planning.Responses@arun.gov.uk>  
**Subject:** BN/65/19/OUT - Bexstone House, Barnham Road, Eastergate, PO20 3RT

Dear Michael,

In relation to the above application, please may EH comment as follows:

- No external lighting shown on the submitted plans shall be installed until details have been submitted to, and approved in writing by the Local Planning Authority prior to the commencement of the development. This submission shall include a layout plan with beam orientation and a schedule of light equipment proposed (luminaire type; mounting height; aiming angles and luminaire profiles). The approved scheme shall be installed, fully assessed by a competent individual when operational to ensure no light creep/bleed, maintained and operated in accordance with the approved details unless the Local Planning Authority gives its written consent to the variation. **Reason:** To protect the appearance of the area/the environment and wildlife/local residents from light pollution.
- No construction/demolition activities shall take place, other than between 08:00 to 18:00 hours (Monday to Friday) and 08:00 to 13:00 hours (Saturday) with no 'noisy' work on Sunday or Bank Holidays. **Reason:** To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031
- If during development, any visible contaminated or odorous material, (for example, asbestos containing material, stained soil, petrol/diesel/solvent odour, underground tanks or associated pipework) not previously identified, is found to be present at the site, no further development (unless otherwise expressly agreed in writing with the Local Planning Authority) shall be carried out until it has been fully investigated using suitably qualified independent consultant(s). The Local Planning Authority must be informed immediately of the nature and degree of the contamination present and a method statement detailing how the unsuspected contamination shall be dealt with must be prepared and submitted to the Local Planning Authority for approval in writing before being implemented. If no such contaminated material is identified during the development, a statement to this effect must be submitted in writing

to the Local Planning Authority. **Reason:** To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

- No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:-
  - a) An indicative programme for carrying out of the works;
  - b) Details of the arrangements for public engagement/consultation both prior to and continued liaison during the construction works;
  - c) Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s);
  - d) Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination;
  - e) The parking of vehicles of site operatives and visitors;
  - f) Loading and unloading of plant and materials, including permitted times for deliveries;
  - g) Storage of plant and materials used in constructing the development;
  - h) The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
  - i) The provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders);
  - j) Measures to control the emission of dust and dirt during construction;
  - k) A scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted.

**Reason:** To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

- Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the “Indoor ambient noise levels for dwellings” guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014. Details complied by a competent acoustician on sound insulation and noise reduction for buildings shall be submitted to and approved in writing by the Local Planning Authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter. **Reason:** To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031
- Prior to occupation of any of the dwellings, a scheme for the provision of facilities to enable the charging of electric vehicles to serve the approved dwellings shall be submitted to the local planning authority for approval and thereafter implemented in accordance with the approved details and the charge points shall thereafter be retained and maintained in good working condition. **Reason:** New petrol and diesel cars / vans will not be sold beyond 2040, and to mitigate against any potential adverse impact of the development on local air quality, in accordance with policy QE DM3 (c) of the Arun Local Plan, the Arun District Council Electric

Informatives:

- The granting of this planning permission does not in any way indemnify against statutory nuisance action being taken should substantiated complaints within the remit of the Environmental Protection Act 1990 be received. For further information, please contact the Environmental Health Department on **01903 737555**.
- The applicant's attention is drawn to the requirements of the Environmental Protection Act 1990 and the Clean Air Act 1993 with regard to burning on site. A statutory nuisance may be caused by smoke and ash from fires or noise from the cutting or chipping trees. In addition, air quality could be adversely affected on large projects. The granting of this planning permission does not permit a statutory nuisance to be caused. The Environment Agency should also be contacted regarding Exemption Permits to burn on site.
- There shall be no burning of any waste or other materials on site, except in an incinerator, the details of which shall be approved in writing by the Local Planning Authority before the development is brought into use. The use approved shall be carried out strictly in accordance with the agreed details. Any deviation from the agreed plan must be agreed in writing with the Local Planning Authority, prior to commencement of the works.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF

Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: [kate.giddings@arun.gov.uk](mailto:kate.giddings@arun.gov.uk)

Visit Arun's web site at [www.arun.gov.uk](http://www.arun.gov.uk)



Save the environment - think before you print.