

-----Original Message-----

From: Vince Carpenter <[REDACTED]>

To: 'Paul Cann' <Paul.Cann@arun.gov.uk>

[REDACTED]

Sent: Tue, 17 May 2022 14:19

Subject: Barnham Court. Roof Water Attenuation. Inspection 17.05.22.

Dear Mr Cann

I report further to my inspection of roof water attenuation measures recently installed at Barnham Court.

The works installed are consistent with our designs noting that a proprietary alternative to the Freeflush system was installed. This system includes leaf guards and a small diameter [circa 15mm] ribbed outlet pipe from each of the rainwater barrels.

The carrier drainage system is in accordance with the general arrangement covered on drawing 31789/EX.01/ P5, noting that works within the local rife will be reviewed by others under a separate application.

I attach for your records photographs of the installed attenuation and carrier drainage system within the demise of Barnham Court.

Kind regards

Vincent Carpenter
Partner

Archibald Shaw
One Little London
Chichester
West Sussex
PO19 1PP



This email and any attachments are confidential to the intended recipient only and may also be privileged. If you have received it in error please delete it from your system and notify the sender.

The copyrights of all attached files on this email are the property of Archibald Shaw LLP and may only be used in connection with the project for which it was prepared.

Registered in England. Registered Office: Archibald Shaw LLP One Little London, Chichester PO19 1PP. Reg No. 003210866

Vincent Carpenter

Partner

Archibald Shaw

One Little London

Chichester

West Sussex PO19 1PP







