

-----Original Message-----

From: Paul Cann <Paul.Cann@arun.gov.uk>

To: Andrewmartin45 <andrewmartin45@aol.com>; phil@archibaldshaw.co.uk
<phil@archibaldshaw.co.uk>

CC: williamjbolland@aol.com <williamjbolland@aol.com>; vince@archibaldshaw.co.uk
<vince@archibaldshaw.co.uk>; Amber Willard <Amber.Willard@arun.gov.uk>

Sent: Tue, 12 Apr 2022 9:34

Subject: RE: Barnham Court - Drainage - BN/17/22/doc

That is correct Andrew.

Regards

Paul Cann

Principal Drainage Engineer

Engineering Services

T: 01903 737819

E: paul.cann@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

From: Andrewmartin45 <andrewmartin45@aol.com>

Sent: 11 April 2022 09:41

To: Paul Cann <Paul.Cann@arun.gov.uk>; phil@archibaldshaw.co.uk

Cc: williamjbolland@aol.com; vince@archibaldshaw.co.uk; Amber Willard
<Amber.Willard@arun.gov.uk>

Subject: Re: Barnham Court - Drainage - BN/17/22/doc

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi

Just so we're clear, are you referring to the following 2 points in respect of the DOC application?

- *Please can the necessary statement be provided by the applicants engineer to confirm physical inspection of the constructed surface water drainage scheme.*
- *Loose gravel has been laid on top of the headwall. Please remove the loose gravel and send in photos as evidence of this*

Regards,

Andrew

-----Original Message-----

From: Paul Cann <Paul.Cann@arun.gov.uk>

To: Andrewmartin45

<andrewmartin45@aol.com>; phil@archibaldshaw.co.uk <phil@archibaldshaw.co.uk>

CC: williamjbolland@aol.com <williamjbolland@aol.com>; vince@archibaldshaw.co.uk <vince@archibaldshaw.co.uk>; Amber Willard <Amber.Willard@arun.gov.uk>

Sent: Mon, 11 Apr 2022 9:27

Subject: RE: Barnham Court - Drainage - BN/17/22/doc

Hi

In this instance, I am happy to deal with the headwall modifications as part of the land drainage consent application and outside of the DOC application.

I believe there are outstanding matters in respect to the DOC application that do require your immediate attention though.

Regards

Paul Cann

Principal Drainage Engineer

Engineering Services

T: 01903 737819

E: paul.cann@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

From: Andrewmartin45 <andrewmartin45@aol.com>

Sent: 11 April 2022 09:15

To: Paul Cann <Paul.Cann@arun.gov.uk>; phil@archibaldshaw.co.uk

Cc: williamjbolland@aol.com; vince@archibaldshaw.co.uk; Amber Willard <Amber.Willard@arun.gov.uk>

Subject: Re: Barnham Court - Drainage - BN/17/22/doc

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Mr Cann,

Our builder is not back on site until end of April, when it can be constructed and photos provided.

Communicating with Amber Willard, will we need to do re-submit another DOC application or not?

Thanks,

Andrew Martin
William Bolland

-----Original Message-----

From: Paul Cann <Paul.Cann@arun.gov.uk>
To: Phil Faulkner <phil@archibaldshaw.co.uk>
CC: William Bolland <williamjbolland@aol.com>; Vince Carpenter
<vince@archibaldshaw.co.uk>; andrewmartin45@aol.com <andrewmartin45@aol.com>
Sent: Mon, 11 Apr 2022 8:52
Subject: RE: Barnham Court - Drainage - BN/17/22/doc

Hi Phil

That's fine. Please can it be constructed asap, as this will form part of the condition discharge. Please can photos also be provided.

Thx

Paul Cann
Principal Drainage Engineer
Engineering Services
T: 01903 737819
E: paul.cann@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

From: Phil Faulkner <phil@archibaldshaw.co.uk>
Sent: 08 April 2022 16:48
To: Paul Cann <Paul.Cann@arun.gov.uk>
Cc: William Bolland <williamjbolland@aol.com>; Vince Carpenter
<vince@archibaldshaw.co.uk>; andrewmartin45@aol.com
Subject: Barnham Court - Drainage - BN/17/22/doc

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Paul

Further to recent correspondence please find attached for your comment / approval our client's proposal on extending the bagwork headwall below ditch bed level.

Kind Regards

Phil Faulkner EngTech MICE
Project Engineer
Archibald Shaw
One Little London
Chichester

West Sussex
PO19 1PP

T: 01243 786471
W: www.archibaldshaw.co.uk

[Click here...](#)

This email and any attachments are confidential to the intended recipient only and may also be privileged. If you have received it in error please delete it from your system and notify the sender.

The copyrights of all attached files on this email are the property of Archibald Shaw LLP and may only be used in connection with the project for which it was prepared.

Registered in England. Registered Office: Archibald Shaw LLP One Little London, Chichester PO19 1PP. Reg No. 0C310866

From: Paul Cann <Paul.Cann@arun.gov.uk>
Sent: 09 February 2022 10:11
To: Phil Faulkner <phil@archibaldshaw.co.uk>
Cc: William Bolland <williamjbolland@aol.com>; Vince Carpenter <vince@archibaldshaw.co.uk>; Jon Lord <JonL@archibaldshaw.co.uk>
Subject: RE: Barnham Court - Drainage [Filed 14 Feb 2022 09:05]

Noted Phil. This is acceptable.

Regards

Paul Cann
Principal Drainage Engineer
Engineering Services
T: 01903 737819
E: paul.cann@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

From: Phil Faulkner <phil@archibaldshaw.co.uk>
Sent: 09 February 2022 10:09
To: Paul Cann <Paul.Cann@arun.gov.uk>
Cc: William Bolland <williamjbolland@aol.com>; Vince Carpenter <vince@archibaldshaw.co.uk>; Jon Lord <JonL@archibaldshaw.co.uk>
Subject: Barnham Court - Drainage

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Paul

Further to our telephone conversation this morning, I confirm your acceptance that the proposed concrete bagwork can be omitted from the base of the existing ditch at the outfall structure.

The concrete bagwork will be placed besides the outfall to the bank face only. The client will provide photographs of the installed outfall.

As noted on our drawings the bagwork will be pinned together and will not extend into the existing ditch.

Regards

Phil Faulkner EngTech MICE
Project Engineer

Archibald Shaw
One Little London
Chichester
West Sussex
PO19 1PP

T: 01243 786471

W: www.archibaldshaw.co.uk

[Click here...](#)

This email and any attachments are confidential to the intended recipient only and may also be privileged. If you have received it in error please delete it from your system and notify the sender.

The copyrights of all attached files on this email are the property of Archibald Shaw LLP and may only be used in connection with the project for which it was prepared.

Registered in England. Registered Office: Archibald Shaw LLP One Little London, Chichester PO19 1PP. Reg No. 0C310866

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
