

From: Joanne Lewis <Joanne.Lewis@arun.gov.uk>
Sent: 31 October 2019 15:45
To: Amber Willard <Amber.Willard@arun.gov.uk>
Subject: RE: air source heat pump

Hi Amber

I have looked at the data supplied and based on this information and the distance to neighbouring properties I would not expect this unit to cause a noise problem to nearby residents. However I would recommend restricting any permission granted to the model specified i.e. Caernarfon CAER410AM0D1. Any change in model would need to be reconsidered in terms of noise.

Joanne

Please note my normal working days are Wednesday, Thursday and Friday.

Joanne Lewis | Senior Environmental Health Officer, [Arun District Council](#) | Location: Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37666 | External: +44 (0) 1903 737666 | E-mail: joanne.lewis@arun.gov.uk
Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

Amber Willard | Planning Officer, Planning Department, Directorate of Place, Arun District Council | Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37445 | External: +44 (0) 1903 737500 Ext: 37445 | E-mail: mailto:amber.willard@arun.gov.uk

Please note this information is given without prejudice and represents the informal view of the officer and not an official opinion of Arun District Council.