


[REDACTED]

Please upload the below and attached to the above application; Drainage, further information



[REDACTED]

Sarah

Further to our conversation earlier today please find enclosed a drawing showing the location of our proposed property (outlined in red) and the new property where we were proposing to use the infiltration results from (outlined in blue), it measures 387m from our site.

The area is well known to have excellent filtration and I hope you can agree that this is near enough for us to assume a filtration rate for our site.

If you are happy with that then I will get the soakaways designed as I discussed earlier today.

Thanks

Matt Bridle BSc (Hons) MRICS

DOWNSVIEW ASSOCIATES

[REDACTED]

This email and any file transmitted with it are confidential and intended solely for the use of the individual to whom they are addressed. If you are not the intended recipient, please notify the sender immediately by using the reply function and then permanently delete what you have received. Consider the environment and print properly.

[REDACTED]

Dear Matt,

Please see below the comments of our Drainage Engineers.

Kind regards

Maria



Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

The information supplied is insufficient to recommend discharge of condition 3 and 7 on application BN/121/19/PL. Whilst the principle of utilising the existing soakaway may be feasible, calculations will need to be provided to show that it meets our requirements, and a detailed drainage layout and construction details will also be required. These calculations will rely upon winter infiltration testing (and groundwater monitoring) as per condition 3.

We provide a [Surface Water Drainage Checklist](#) which applicants are guided to in an informative on their decision notice, this makes clear the level of detail required in terms of testing, calculations, the drainage layout and the construction detail drawings. Given that we are currently months away from the winter period, unless the applicant is able to provide winter results from a previous year, I would recommend that the application is refused and a new submission is made in early 2021.

Kind Regards

Sarah Burrow

Engineering Assistant, Engineers

Current Working Hours:

Monday-Wednesday, Friday: 8:00 – 17:00

Thursday 8:00 – 11:00

Some of this time is spent on site.



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)



To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: BN/81/20/DOC

Registered: 23rd July 2020

Site Address: Swallowfield Eastergate Lane Eastergate PO20 3SJ

Description of Works: Approval of details reserved by condition imposed under ref BN/121/19/PL relating to Condition Nos 3 - surface water drainage, 4 - Construction Management Plan, 5 - materials & finishes, 6 - hard & soft landscaping, 7 - drainage scheme, 8 - storage of waste and 13 - renewable energy.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **7th August 2020**.


Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Maria Tomalova

Planning Case Officer- Arun District Council



PLCOND00 (QDB) 2020

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
